

NOTE: **MAY 10 1978**

White Copy - Division's Copy
 Green Copy - Driller's Copy
 Yellow Copy - Owner's Copy

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Eastman

2. LOCATION SE Section 12 Township 8N Range 5W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE
 OR - Grid or Street No. Street Name ADDRESS Jesse Miller
RFD

AND - If available subdivision name, lot & block No. POST OFFICE Steubens Wis. 54626

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 20'

Sanitary Bldg. Drain		Sanitary Bldg. Sewer		Floor Drain Connected To:		Storm Bldg. Drain		Storm Bldg. Sewer	
C.I.	Other	C.I.	Other	C.I. Sewer	Other Sewer	C.I.	Other	C.I.	Other

Street Sewer: San. Storm Other Sewers: C.I. Other Foundation Drain Connected to: Sewer Clearwater Dr. Sewage Sump Clearwater Sump Sewage Absorption Unit: Seepage Pit Seepage Bed Seepage Trench 70'

Clearwater Sump 65' Holding Tank Septic Tank

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Trailer home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>63</u>	<u>6</u>	<u>63</u>	<u>100</u>

9. FORMATIONS

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>15</u>
<u>soft sandstone</u>	<u>15</u>	<u>40</u>
<u>limestone</u>	<u>40</u>	<u>100</u>

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel P.E. 18.97 A-53</u>	<u>Surface</u>	<u>63</u>
	<u>Valley Steel</u>		
	<u>Bitless adaptor</u>		

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with Air Water

Rotary-air w/drilling mud Rotary-hammer & air

Rotary-w/drilling mud Reverse Rotary

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>7</u>
<u>Cement</u>	<u>7</u>	<u>63</u>

Well construction completed on 4-7- 19 78

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 5 GPM

Depth from surface to normal water level 55 Ft.

Depth of water level when pumping 72 Ft. Stabilized Yes No

Well is terminated 10 inches above below final grade

Well disinfected upon completion Yes No

Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 5-2- 19 78

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Kopion Registered Well Driller Complete Mail Address Rosobel, Wis. R3 Box 84 53805