

NOTE:

White Copy - Division's Copy
 Green Copy - Driller's Copy
 Yellow Copy - Owner's Copy

WELL CONSTRUCTOR'S REPORT

Form 3300-15

Rev. 12-76
 AUG 18 1978

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Eastman

2. LOCATION SE 15 8N 5W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE William F. Bowler

OR - Grid or Street No. Street Name ADDRESS R 1

AND - If available subdivision name, lot & block No. POST OFFICE Mauney, Wis. 53826

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 30' Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to: Sewage Sump Clearwater Sump Sewage Absorption Unit 175' Seepage Pit Seepage Bed Seepage Trench

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit 200'

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Farm home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	340	6	340	380	Clay	Surface	20
						limestone	20	265
						soft sandstone	265	320
						limestone	320	380

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
6	new black steel P.E. 18.97 A-53	Surface	340
	Kent Steel		
	Bitless adaptor		

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
Clay	Surface	7
Cement	7	340

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with Air Water

Rotary-air w/drilling mud Rotary-hammer & air

Rotary-w/drilling mud Reverse Rotary

Well construction completed on 7-28-1978

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 5 GPM Well is terminated 10 inches above final grade below

Depth from surface to normal water level 310 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 340 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 8-15-1978

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Cospian Registered Well Driller Complete Mail Address Boacobal, Wis. R3 Box 84 53805

599