

MAY 29 1979

1. COUNTY <u>Crawford</u>		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City		Name <u>Marietta</u>	
2. LOCATION OR - Grid or Street No. <u>SW</u> Section <u>16</u> Township <u>8N</u> Range <u>5W</u>		3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE <u>Bell Telephone Co.</u>		ADDRESS <u>Steuben</u>	
AND - If available subdivision name, lot & block No.		POST OFFICE <u>WV, 54657</u>			
4. Distance in feet from well to nearest: (Record answer in appropriate block) <u>10'</u>		Building		Sanitary Bldg. Drain	
		Sanitary Bldg. Sewer		Floor Drain Connected To:	
		Storm Bldg. Drain		Storm Bldg. Sewer	
		San. C.I.		C.I. Sewer	
		Other		Other Sewer	
		C.I.		C.I.	
		Other		Other	
Street Sewer		Other Sewers		Foundation Drain Connected to:	
San. Storm		C.I. Other		Sewage Sump	
				Clearwater Sump	
				Septic Tank	
				Holding Tank	
				Sewage Absorption Unit	
				Seepage Pit	
				Seepage Bed	
				Seepage Trench	
Privy		Pet Waste Pit		Pit: Nonconforming Existing	
				Well	
				Pump	
				Tank	
				Subsurface Pumproom	
				Nonconforming Existing	
				Barn Gutter	
				Animal Barn Pen	
				Animal Yard	
				Silo With Pit	
				Glass Lined Storage Facility	
				Silo w/o Pit	
				Earthen Silage Storage Trench Or Pit	
Temporary Manure Stack		Watertight Liquid Manure Tank		Solid Manure Storage Structure	
				Subsurface Gasoline or Oil Tank	
				Waste Pond or Land Disposal Unit (Specify Type)	
				Other (Give Description)	
5. Well is intended to supply water for: <u>Refrigeration only</u>		9. FORMATIONS			
6. DRILLHOLE		Kind		From (ft.) To (ft.)	
Dia. (in.) From (ft.) To (ft.) Dia. (in.) From (ft.) To (ft.)		<u>Clay & sand</u>		Surface <u>0</u> <u>15</u>	
<u>10</u> <u>Surface</u> <u>0</u> <u>47</u> <u>6</u> <u>47</u> <u>80</u>		<u>hard shalestone</u>		<u>15</u> <u>80</u>	
7. CASING, LINER, CURBING AND SCREEN					
Material, Weight, Specification & Method of Assembly		From (ft.) To (ft.)			
Dia. (in.)		From (ft.) To (ft.)			
<u>6" new black steel P.E. 18.97 A-53</u>		Surface <u>0</u> <u>47</u>			
<u>Kent Steel</u>					
<u>Pitless adaptor</u>					
8. GROUT OR OTHER SEALING MATERIAL		10. TYPE OF DRILLING MACHINE USED			
Kind		From (ft.) To (ft.)		<input type="checkbox"/> Cable Tool	
Clay		Surface <u>0</u> <u>8</u>		<input type="checkbox"/> Rotary-hammer w/drilling mud & air	
Cement		<u>8</u> <u>47</u>		<input type="checkbox"/> Jetting with	
				<input type="checkbox"/> Air	
				<input type="checkbox"/> Water	
				<input checked="" type="checkbox"/> Rotary-air w/drilling mud	
				<input checked="" type="checkbox"/> Rotary-hammer & air	
				<input type="checkbox"/> Reverse Rotary	
				<input type="checkbox"/> Rotary-w/drilling mud	
11. MISCELLANEOUS DATA		Well construction completed on <u>4-9-1979</u>			
Yield Test: <u>3</u> Hrs. at <u>5</u> GPM		Well is terminated <u>10</u> inches <input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below			
Depth from surface to normal water level <u>50</u> Ft.		Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
Depth of water level when pumping <u>58</u> Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
Water sample sent to <u>Madison</u> laboratory on <u>5-21-1979</u>					

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Copian Registered Well Driller Complete Mail Address R3 Box 84 Boscobel, WV, 53805

602