

1. COUNTY Crawford CHECK ONE Town Village City NAME Marietta
 2. LOCATION (Number and street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.)
NE Part of Sec. 16 T8N R5W

3. OWNER AT TIME OF DRILLING John Cornwell
 4. OWNER'S COMPLETE MAIL ADDRESS R 7 D Steuben

5. Distance in feet from well to nearest: (Record answer in appropriate block)		BUILDING	SANITARY SEWER	FLOOR DRAIN	FOUNDATION DRAIN	WASTE WATER DRAIN
		C. I.	TILE	C. I.	SEWER CONNECTED	INDEPENDENT
		15'	25'			
CLEAR WATER DRAIN	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILLO
C. I.	TILE					
	60'	0	70'	0	0	0
						50'
						0

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)
None

6. Well is intended to supply water for: Trailer Home

7. DRILLHOLE						10. FORMATIONS			
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
10	Surface	45	6	45	100	Clay	Surface	18	
						lime rock	18	75	
						sandstone	75	100	

8. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6	black plain end standard 19.18	Surface	55

9. GROUT OR OTHER SEALING MATERIAL		
Kind	From (ft.)	To (ft.)
Clay	Surface	18
Cement	18	55

11. MISCELLANEOUS DATA
 Yield test: 3 Hrs. at 18 GPM
 Well is terminated 10 inches above below final grade
 Depth from surface to normal water level 60 ft. Well disinfected upon completion Yes No
 Depth to water level when pumping 70 ft. Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on: 6-22 1967

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumphrooms, access pits, etc., should be given on reverse side.

SIGNATURE Benneth Empson Registered Well Driller COMPLETE MAIL ADDRESS R 3 Box 36 Boscobel, Wis. 53805

Please do not write in space below

COLIFORM TEST RESULT	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
605				