

NOTE:

White Copy - Division's Copy  
Green Copy - Driller's Copy  
Yellow Copy - Owner's Copy

MAR 28 1978

1. COUNTY Crawford CHECK (✓) ONE:  Town  Village  City Name Eastman

2. LOCATION SE Section 17 Township 8N Range 5W 3. NAME  OWNER  AGENT AT TIME OF DRILLING CHECK (✓) ONE  
OR - Grid or Street No. Street Name ADDRESS Floyd Klevens  
R 300

AND - If available subdivision name, lot & block No. POST OFFICE Eastman, Wis., 54626

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 12'

| Sanitary Bldg. Drain |       | Sanitary Bldg. Sewer |       | Floor Drain Connected To: |             | Storm Bldg. Drain |       | Storm Bldg. Sewer |       |
|----------------------|-------|----------------------|-------|---------------------------|-------------|-------------------|-------|-------------------|-------|
| C.I.                 | Other | C.I.                 | Other | C.I. Sewer                | Other Sewer | C.I.              | Other | C.I.              | Other |

Street Sewer: San. Storm Other Sewers: C.I. Other Foundation Drain Connected to: Sewage Sump: C.I. Other Clearwater Sump: Clearwater Dr. Sewage Sump Clearwater Sump

Septic Tank: 300 Holding Tank: 350' Sewage Absorption Unit: Seepage Pit Seepage Bed Seepage Trench

Privy: Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom: Nonconforming Existing Barn Gutter: 300' Animal Barn Pen Animal Yard: 450' Silo With Pit: 450' Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Country home

6. DRILLHOLE

| Dia. (in.) | From (ft.)     | To (ft.)   | Dia. (in.) | From (ft.) | To (ft.)   |
|------------|----------------|------------|------------|------------|------------|
| <u>10</u>  | <u>Surface</u> | <u>329</u> | <u>6</u>   | <u>329</u> | <u>410</u> |

9. FORMATIONS

| Kind                  | From (ft.)     | To (ft.)   |
|-----------------------|----------------|------------|
| <u>Clay</u>           | <u>Surface</u> | <u>20</u>  |
| <u>limestone</u>      | <u>20</u>      | <u>50</u>  |
| <u>blue limestone</u> | <u>50</u>      | <u>150</u> |
| <u>soft sandstone</u> | <u>150</u>     | <u>300</u> |
| <u>limestone</u>      | <u>300</u>     | <u>325</u> |
| <u>hard sandstone</u> | <u>325</u>     | <u>410</u> |

7. CASING, LINER, CURBING AND SCREEN

| Dia. (in.) | Material, Weight, Specification & Method of Assembly                | From (ft.)     | To (ft.)   |
|------------|---|----------------|------------|
| <u>6</u>   | <u>new black steel P.E. 18.97 A-53 Valley Steel Pitless adaptor</u> | <u>Surface</u> | <u>329</u> |

10. TYPE OF DRILLING MACHINE USED

Cable Tool  Rotary-hammer w/drilling mud & air  Jetting with  Air  Water

Rotary-air w/drilling mud  Rotary-hammer & air

Rotary-w/drilling mud  Reverse Rotary

8. GROUT OR OTHER SEALING MATERIAL

| Kind          | From (ft.)     | To (ft.)   |
|---------------|----------------|------------|
| <u>Clay</u>   | <u>Surface</u> | <u>7</u>   |
| <u>Cement</u> | <u>7</u>       | <u>329</u> |

Well construction completed on 2-28-1978

Well is terminated 12 inches  above final grade  below

Well disinfected upon completion  Yes  No

Well sealed watertight upon completion  Yes  No

11. MISCELLANEOUS DATA

Yield Test: 8 Hrs. at 5 GPM

Depth from surface to normal water level 315 Ft.

Depth of water level when pumping 345 Ft. Stabilized  Yes  No

Water sample sent to Madison laboratory on 3-21-1978

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Coplan Registered Well Driller 606

Complete Mail Address Boscobel, Wis. R3 Box 84 53805