

NOTE:

White Copy - Division's Copy
 Green Copy - Driller's Copy
 Yellow Copy - Owner's Copy

MAY 29 1979

1. COUNTY <u>Crawford</u>		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City		Name <u>Marietta</u>	
2. LOCATION ¼ Section <u>NW</u> Section <u>17</u> Township <u>8N</u> Range <u>5W</u>		3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE <u>George Wallin</u>		ADDRESS <u>Box 506</u>	
OR - Grid or Street No. Street Name		POST OFFICE <u>Stephens Wis, 54647</u>		AND - If available subdivision name, lot & block No.	
4. Distance in feet from well to nearest: (Record answer in appropriate block) <u>8'</u>		Sanitary Bldg. Drain C.I. Other		Sanitary Bldg. Sewer C.I. Other	
Floor Drain Connected To: C.I. Sewer Other Sewer		Storm Bldg. Drain C.I. Other		Storm Bldg. Sewer C.I. Other	
Street Sewer San. Storm		Other Sewers C.I. Other		Foundation Drain Connected to: Sewer Clearwater Dr. Sewage Sump Clearwater Sump	
Sewage Sump C.I. Other		Clearwater Sump		Septic Tank <u>60'</u>	
Holding Tank		Sewage Absorption Unit Seepage Pit Seepage Bed Seepage Trench		<u>70'</u>	
Privy Pet Waste Pit		Pit: Nonconforming Existing Well Pump Tank		Subsurface Pumproom Nonconforming Existing	
Barn Gutter		Animal Barn Pen		Animal Yard	
Silo With Pit		Glass Lined Storage Facility		Silo w/o Pit	
Earthen Silage Storage Trench Or Pit		Temporary Manure Stack		Watertight Liquid Manure Tank	
Solid Manure Storage Structure		Subsurface Gasoline or Oil Tank		Waste Pond or Land Disposal Unit (Specify Type)	
Other (Give Description)					
5. Well is intended to supply water for: <u>Country home</u>		9. FORMATIONS			
6. DRILLHOLE		Kind		From (ft.) To (ft.)	
Dia. (in.) From (ft.) To (ft.) Dia. (in.) From (ft.) To (ft.)		<u>loose sand</u>		<u>Surface 0 40</u>	
<u>6 Surface 0 80</u>		<u>sandstone</u>		<u>40 80</u>	
7. CASING, LINER, CURBING AND SCREEN					
Material, Weight, Specification & Method of Assembly		From (ft.) To (ft.)			
<u>6 new black steel P.E. 18.97 A-53 Kent Steel Pitless adaptor</u>		<u>Surface 0 61</u>			
8. GROUT OR OTHER SEALING MATERIAL		10. TYPE OF DRILLING MACHINE USED			
Kind From (ft.) To (ft.)		<input type="checkbox"/> Cable Tool		<input type="checkbox"/> Rotary-hammer w/drilling mud & air	
<u>loose sand Surface 0 40</u>		<input type="checkbox"/> Rotary-air w/drilling mud		<input checked="" type="checkbox"/> Rotary-hammer & air	
		<input type="checkbox"/> Rotary-w/drilling mud		<input type="checkbox"/> Reverse Rotary	
				<input type="checkbox"/> Jetting with <input type="checkbox"/> Air <input type="checkbox"/> Water	
		Well construction completed on <u>April 11 - 19 79</u>			
11. MISCELLANEOUS DATA		Well is terminated <u>12</u> inches <input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below			
Yield Test: <u>2</u> Hrs. at <u>5</u> GPM		Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
Depth from surface to normal water level <u>45</u> Ft.		Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
Depth of water level when pumping <u>62</u> Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No					
Water sample sent to <u>Madison</u> laboratory on <u>5-21-19 79</u>					
Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.					
Signature <u>608 Kenneth Copron</u> Registered Well Driller		Complete Mail Address <u>R3 Box 84 Boscobel Wis, 53805</u>			