

NOTE:

White Copy - Division's Copy
Green Copy - Driller's Copy
Yellow Copy - Owner's Copy

JUN 17 1977 WELL CONSTRUCTOR'S REPORT

Form 3300-15
Rev. 10-75

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Eastman
2. LOCATION NW Section 19 Township 8N Range 5W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE
OR - Grid or Street No. Street Name ADDRESS Milo Cooper
R7D
AND - If available subdivision name, lot & block No. POST OFFICE Eastman, Wis. 54626

4. Distance in feet from well to nearest: (Record answer in appropriate block) 15'
Building Sanitary Bldg. Drain Sanitary Bldg. Sewer Floor Drain Connected To: Storm Bldg. Drain Storm Bldg. Sewer
C.I. Other C.I. Other C.I. Sewer Other Sewer C.I. Other C.I. Other
Street Sewer Other Sewers Foundation Drain Connected to: Sewage Sump Clearwater Sump Septic Tank Holding Tank Sewage Absorption Unit 120'
San. Storm C.I. Other Sewer Sewage Sump Clearwater Dr. C.I. Other Clearwater Sump Septic Tank Holding Tank Seepage Pit Seepage Bed Seepage Trench
Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit
Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Country home
6. DRILLHOLE
Dia. (in.) From (ft.) To (ft.) Dia. (in.) From (ft.) To (ft.) Kind From (ft.) To (ft.)
10 Surface 0 50 6 50 470 Clay Surface 0 10
limestone 10 170
sandstone 170 220
limestone 220 470

7. CASING, LINER, CURBING AND SCREEN
Dia. (in.) Material, Weight, Specification & Method of Assembly From (ft.) To (ft.)
6 new black steel P.E. 18,97 A-53 Surface 0 50
Valley Steel Pitless adaptor

8. GROUT OR OTHER SEALING MATERIAL
Kind From (ft.) To (ft.)
Clay Surface 0 7
Cement 7 50

10. TYPE OF DRILLING MACHINE USED
 Cable Tool Rotary-hammer w/drilling mud & air Jetting with
 Rotary-air w/drilling mud Rotary-hammer & air Air
 Rotary-w/drilling mud Reverse Rotary Water
Well construction completed on 6-7- 1977

11. MISCELLANEOUS DATA
Yield Test: 3 Hrs. at 6 GPM Well is terminated 10 inches above below final grade
Depth from surface to normal water level 360 Ft. Well disinfected upon completion Yes No
Depth of water level when pumping 390 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 6-13- 1977

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature 617 Kenneth Coplan Registered Well Driller Complete Mail Address Boscobel, Wis. 53805
R3 Box 84