

**WELL CONSTRUCTOR'S REPORT TO WISCONSIN STATE BOARD OF HEALTH**  
See Instructions on Reverse Side

1. County Crawford { Town  Village  City  Eastman Check one and give name T8N R6W  
 2. Location Sec. 3 Tr. of Eastman Bl. 8 **RECEIVED**  
 Name of street and number of premise or Sec. Tn. and R. numbers  
 3. Owner  or Agent  Everett Backen NOV 14 1949  
 Name of individual, partnership or firm  
 4. Mail Address Eastman Wis. R.F.D. BUREAU  
 Complete address required SAN. ENG.  
 5. From well to nearest: Building 200 ft; sewer — ft; drain — ft; septic tank — ft;  
 dry well or filter bed — ft; abandoned well — ft.

6. Well is intended to supply water for: Stock & Home Use

**7. DRILLHOLE:**

Dia. (in.)	From (ft.)	To (ft.)
8"	0	30
6"	30	238
4"	238	436
3"	436	439

**8. CASING AND LINER PIPE OR CURBING:**

Dia. (in.)	Kind	From (ft.)	To (ft.)
3"	Galv. Steel Casing	0	438

**9. GROUT:**

Kind	From (ft.)	To (ft.)
Clay Red Puddled	0	438

**10. FORMATIONS:**

Kind	From (ft.)	To (ft.)
Broken Limestone	0	10
Blue Limestone	10	112
Hard Bluff	112	208
Soft Bluff	208	236
White Limestone	236	302
Blue Limestone	302	361
White Limestone	361	415
Sandstone	415	436
Soft sand	436	438
Water	438	439
Sand		

**11. MISCELLANEOUS DATA:**

Yield test: 2 Hrs. at 10 GPM.  
 Depth from surface to water: 423 ft.  
 Water-level when pumping: 423 ft.  
 Water sample sent to laboratory at \_\_\_\_\_ on \_\_\_\_\_ 19\_\_\_\_

Construction of the well was completed on October 24 1949.  
 The well is terminated 12 inches  above, below  the permanent ground surface.  
 Was the well disinfected upon completion? Yes \_\_\_\_\_ No X  
 Was the well sealed watertight upon completion? Yes X No \_\_\_\_\_

Signature Fred W. Schultz & Son Registered Well Driller Complete Mail Address Farmersburg Iowa  
Farmersburg Well Co.

624