

WELL CONSTRUCTOR'S REPORT

DEPARTMENT OF RESOURCE DEVELOPMENT

Well 6

1. COUNTY <i>Crawford</i>		CHECK ONE <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City		NAME <i>Eastman</i>		
2. LOCATION (Number and Street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.) <i>NW Part of Sec. 9 T 8 N R 6 W</i>						
3. OWNER AT TIME OF DRILLING <i>Ronald Roth Fritsche</i>						
4. OWNER'S COMPLETE MAIL ADDRESS <i>R1 Eastman, Wis. 54626</i>						
5. Distance in feet from well to nearest: (Record answer in appropriate block)		BUILDING C. I.	SANITARY SEWER TILE	FLOOR DRAIN C. I.	FOUNDATION DRAIN SEWER CONNECTED/INDEPENDENT	WASTE WATER DRAIN C. I.
		<i>300'</i>	<i>300'</i>	<i>300'</i>		
CLEAR WATER DRAIN C. I.	SEPTIC TANK TILE	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO
	<i>325'</i>		<i>325'</i>		<i>400'</i>	<i>400'</i>
OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)						

6. Well is intended to supply water for: *Farm home*

7. DRILLHOLE						10. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
<i>9"</i>	<i>Surface</i>	<i>515</i>	<i>6</i>	<i>515</i>	<i>660</i>	<i>Clay</i>	<i>Surface</i>	<i>16</i>
						<i>lime rock</i>	<i>16</i>	<i>150</i>
						<i>Clay</i>	<i>150</i>	<i>160</i>
						<i>soft sand rock</i>	<i>160</i>	<i>460</i>
						<i>hard sand stone</i>	<i>460</i>	<i>570</i>
						<i>blue rock</i>	<i>570</i>	<i>660</i>

8. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
<i>5</i>	<i>black - new plain ends 14.81</i>	<i>Surface</i>	<i>515</i>

9. GROUT OR OTHER SEALING MATERIAL			
Kind	From (ft.)	To (ft.)	
<i>Clay</i>	<i>Surface</i>	<i>480</i>	
<i>Cement</i>	<i>480</i>	<i>490</i>	

11. MISCELLANEOUS DATA			
Yield test:	<i>15 Hrs. at</i>	<i>12 GPM</i>	Well is terminated <i>10</i> inches <input checked="" type="checkbox"/> above <input type="checkbox"/> below final grade
Depth from surface to normal water level	<i>580</i>	ft.	Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Depth to water level when pumping	<i>580</i>	ft.	Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Water sample sent to <i>Madison</i>			laboratory on: <i>3-18-</i> 1968

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE <i>Kenneth Lopian</i>	Registered Well Driller	COMPLETE MAIL ADDRESS <i>53805 R3 Box 84 Boscobel, Wis.</i>
------------------------------------	-------------------------	--

COLIFORM TEST RESULT <i>634</i>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
------------------------------------	---------------	---------------	-----------	---------

Please do not write in space below