

NOTE:

White Copy - Division's Copy  
 Green Copy - Driller's Copy  
 Yellow Copy - Owner's Copy

JUL 16 1979

1. COUNTY <u>Crawford</u>		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City Name <u>West Eastman</u>	
2. LOCATION 1/4 Section <u>NE</u> Section <u>14</u> Township <u>8N</u> Range <u>6&amp;W</u>		3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE <u>LeRoy L. Trautsch</u>	
OR - Grid or Street No. Street Name		ADDRESS <u>RFD</u>	
AND - If available subdivision name, lot & block No.		POST OFFICE <u>Eastman, Wv., 54626</u>	
4. Distance in feet from well to nearest: (Record answer in appropriate block) <u>40'</u>		Sanitary Bldg. Drain: C.I. Other	
Sanitary Bldg. Sewer: C.I. Other		Floor Drain Connected To: C.I. Sewer Other Sewer	
Storm Bldg. Drain: C.I. Other		Storm Bldg. Sewer: C.I. Other	
Street Sewer: San. Storm		Sewage Absorption Unit: <u>120'</u> Seepage Pit Seepage Bed Seepage Trench	
Other Sewers: C.I. Other		Sewage Sump: C.I. Other	
Foundation Drain Connected to: Sewer Clearwater Dr.		Clearwater Sump	
Septic Tank		Holding Tank	
Privy		Sewage Absorption Unit	
Pet Waste Pit		Sewage Sump	
Pit: Nonconforming Existing		Clearwater Sump	
Well		Animal Barn Pen	
Pump		Animal Yard	
Tank		Silo With Pit	
Subsurface Pumproom		Glass Lined Storage Facility	
Nonconforming Existing		Silo w/o Pit	
Barn Gutter		Earthen Silage Storage Trench Or Pit	
Waste Pond or Land Disposal Unit (Specify Type)		Other (Give Description)	
Temporary Manure Stack		Watertight Liquid Manure Tank	
Solid Manure Storage Structure		Subsurface Gasoline or Oil Tank	
5. Well is intended to supply water for: <u>Country home</u>		9. FORMATIONS	
6. DRILLHOLE		Kind	
Dia. (in.) From (ft.) To (ft.)		From (ft.) To (ft.)	
<u>10</u> <u>Surface</u> <u>72</u>		<u>Clay &amp; stone</u> <u>Surface</u> <u>0</u> <u>55</u>	
<u>6</u> <u>72</u> <u>140</u>		<u>hard limestone</u> <u>55</u> <u>140</u>	
7. CASING, LINER, CURBING AND SCREEN		10. TYPE OF DRILLING MACHINE USED	
Material, Weight, Specification & Method of Assembly		<input type="checkbox"/> Cable Tool <input type="checkbox"/> Rotary-hammer w/drilling mud & air <input type="checkbox"/> Rotary-air w/drilling mud <input checked="" type="checkbox"/> Rotary-hammer & air <input type="checkbox"/> Rotary-w/drilling mud <input type="checkbox"/> Reverse Rotary <input type="checkbox"/> Jetting with <input type="checkbox"/> Air <input type="checkbox"/> Water	
Dia. (in.) From (ft.) To (ft.)		Well construction completed on <u>7-5-1979</u>	
<u>6</u> <u>new black steel</u> <u>Surface</u> <u>0</u> <u>72</u>		Well is terminated <u>12</u> inches <input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below	
<u>P.E. 18.97</u>		Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
<u>A-53</u>		Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
<u>Valley Steel</u>		Water sample sent to <u>Madison</u> laboratory on <u>7-10-1979</u>	
<u>Pitless Adaptor</u>		Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.	
8. GROUT OR OTHER SEALING MATERIAL		Signature <u>Kenneth Coplan</u> Registered Well Driller	
Kind From (ft.) To (ft.)		Complete Mail Address <u>Boonville, Wv.</u> <u>R2 Box 4</u> <u>53805</u>	
<u>Clay</u> <u>Surface</u> <u>0</u> <u>7</u>			
<u>Cement</u> <u>7</u> <u>72</u>			
11. MISCELLANEOUS DATA			
Yield Test: <u>2</u> Hrs. at <u>5</u> GPM			
Depth from surface to normal water level <u>100</u> Ft.			
Depth of water level when pumping <u>108</u> Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			

637