

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Eastman

2. LOCATION SW Section 18 Township 8N Range 7W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE
Martin W. Bunts

OR - Grid or Street No. Street Name (6) ADDRESS RFD Box 45

AND - If available subdivision name, lot & block No. POST OFFICE Eastman, Wis., 54626

4. Distance in feet from well to nearest: (Record answer in appropriate block) 20'

Building		Sanitary Bldg. Drain		Sanitary Bldg. Sewer		Floor Drain Connected To:		Storm Bldg. Drain		Storm Bldg. Sewer	
C.I.	Other	C.I.	Other	C.I.	Other	C.I. Sewer	Other Sewer	C.I.	Other	C.I.	Other

Street Sewer		Other Sewers		Foundation Drain Connected to:		Sewage Sump		Clearwater Sump		Septic Tank		Holding Tank		Sewage Absorption Unit	
San.	Storm	C.I.	Other	Sewer	Clearwater Dr.	Sewage Sump	Clearwater Sump	C.I.	Other	C.I.	Other	C.I.	Other	Seepage Pit	Seepage Bed

65'

Privy	Pet Waste Pit	Pit: Nonconforming Existing	Well	Pump	Tank	Subsurface Pumproom	Nonconforming Existing	Barn Gutter	Animal Barn Pen	Animal Yard	Silo With Pit	Glass Lined Storage Facility	Silo w/o Pit	Earthen Silage Storage Trench Or Pit
-------	---------------	-----------------------------	------	------	------	---------------------	------------------------	-------------	-----------------	-------------	---------------	------------------------------	--------------	--------------------------------------

Temporary Manure Stack	Watertight Liquid Manure Tank	Solid Manure Storage Structure	Subsurface Gasoline or Oil Tank	Waste Pond or Land Disposal Unit (Specify Type)	Other (Give Description)
------------------------	-------------------------------	--------------------------------	---------------------------------	---	--------------------------

5. Well is intended to supply water for: Trailer home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10	Surface	66	6	66	80

9. FORMATIONS

Kind	From (ft.)	To (ft.)
Clay & loose stone	Surface	40
hard shale stone	40	80

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
6	new black steel P.E. 18.97	Surface	66
	A-53		
	Kent Steel		
	Pitless adaptor		

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
Clay	Surface	10
Cement	10	66

10. TYPE OF DRILLING MACHINE USED

<input type="checkbox"/> Cable Tool	<input type="checkbox"/> Rotary-hammer w/drilling mud & air	<input type="checkbox"/> Jetting with
<input type="checkbox"/> Rotary-air w/drilling mud	<input checked="" type="checkbox"/> Rotary-hammer & air	<input type="checkbox"/> Air
<input type="checkbox"/> Rotary-w/drilling mud	<input type="checkbox"/> Reverse Rotary	<input type="checkbox"/> Water

Well construction completed on 11-6-78

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 5 GPM

Depth from surface to normal water level 42 Ft.

Depth of water level when pumping 62 Ft. Stabilized Yes No

Well is terminated 12 inches above below final grade

Well disinfected upon completion Yes No

Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 11-27-78

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Copian Registered Well Driller Complete Mail Address Boscobel, Wis., R3 Box 84 53805

641