

**WELL CONSTRUCTOR'S REPORT**  
FORM 3300-15

STATE OF WISCONSIN  
DEPARTMENT OF NATURAL RESOURCES  
Box 450  
Madison, Wisconsin 53701

**NOTE**  
WHITE COPY - DIVISION'S COPY  
GREEN COPY - DRILLER'S COPY  
YELLOW COPY - OWNER'S COPY

<b>1. COUNTY</b> Crawford	<b>CHECK ONE</b>	<b>NAME</b>
	<input type="checkbox"/> Town <input checked="" type="checkbox"/> Village <input type="checkbox"/> City	Eastman

<b>2. LOCATION -</b> 1/4 Section	Section	Township	Range	<b>3. OWNER AT TIME OF DRILLING</b>
NW 1/4 NW 1/4	19	8 N	6 W	U. Stuart Asche
OR - Grid or street no.				ADDRESS
Street name				R.R. 1

AND - If available subdivision name, lot & block no.

POST OFFICE  
Praire Du Chein, Wisc.

<b>4. Distance in feet from well to nearest:</b> (Record answer in appropriate block)	BUILDING	SANITARY SEWER	FLOOR DRAIN	FOUNDATION DRAIN	WASTE WATER DRAIN
	C.I.	TILE	C.I.	SEWER CONNECTED	INDEPENDENT
	10	25	None	None	25
<b>CLEAR WATER DRAIN</b>	<b>SEPTIC TANK</b>	<b>PRIVY</b>	<b>SEEPAGE PIT</b>	<b>ABSORPTION FIELD</b>	<b>BARN</b>
C.I.	TILE				SILO
None	60	None	100	None	None
					ABANDONED WELL
					SINK HOLE
					None

**OTHER POLLUTION SOURCES** (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)  
None

**5. Well is intended to supply water for:**  
House

<b>6. DRILLHOLE</b>						<b>9. FORMATIONS</b>		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	120				Clay	Surface	16
6	120	516				Brn. Limestone with Flint	16	110

<b>7. CASING, LINER, CURBING, AND SCREEN</b>				<b>10. TYPE OF DRILLING MACHINE USED</b>		
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)	<input checked="" type="checkbox"/> Cable Tool	<input type="checkbox"/> Direct Rotary	<input type="checkbox"/> Reverse Rotary
6	Steel P.E. 18.97	Surface	120	<input type="checkbox"/> Rotary - air w/drilling mud	<input type="checkbox"/> Rotary - hammer with drilling mud & air	<input type="checkbox"/> Jetting with Air <input type="checkbox"/> Water
				Well construction completed on 6-26 1971		
				Well is terminated 10 inches <input checked="" type="checkbox"/> above <input type="checkbox"/> below final grade		
				Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		

<b>8. GROUT OR OTHER SEALING MATERIAL</b>			
Kind	From (ft.)	To (ft.)	
Neat Cement	Surface	120	

<b>11. MISCELLANEOUS DATA</b>			
Yield test:	5	Hrs. at 9	GPM
Depth from surface to normal water level	330	ft.	
Depth to water level when pumping	380	ft.	

Water sample sent to State Lab. of Hygiene, Madison      laboratory on: 6-29 19 71

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

<b>SIGNATURE</b> <i>Duane Lubbers</i> Duane Lubbers      W.D. 410 Registered Well Driller	<b>COMPLETE MAIL ADDRESS</b> Duane Lubbers Farmersburg, Iowa 52047
--	--

Please do not write in space below

COLIFORM TEST RESULT 645	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
-----------------------------	---------------	---------------	-----------	---------

REV. 3-71