

NOTE:

White Copy - Division's Copy
Green Copy - Driller's Copy
Yellow Copy - Owner's Copy

JUL 14 1986

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Marietta

2. LOCATION NW of SE Section 29 Township 8N Range 4W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE F L Huesmann (Huesmann?)

OR - Grid or Street No. Street or Road Name ADDRESS 103 Kingston Way

AND - If available subdivision name, lot & block No. POST OFFICE Waunakee Wis ZIP CODE 53597

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 25' Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm C.I. Other Other Sewers C.I. Other Foundation Drain Connected to: Sewer Clearwater Dr. Sewage Sump C.I. Other Clearwater Sump Clearwater Sump

Septic Tank not dx Holding Tank Sewage Absorption Unit: Seepage Pit Seepage Bed Seepage Trench Manure Hopper or Retention or Pneumatic Tank

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumphoom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit Earthen Manure Basin

Temporary Manure Stack or Platform Watertight Liquid Manure Tank or Basin Manure Pressure Pipe Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Manure Storage Basin Concrete Floor Only Concrete Floor and Partial Concrete Walls Other (Describe)

5. Well is intended to supply water for: home 9. FORMATIONS

Kind	From (ft.)	To (ft.)
<u>clay rock</u>	<u>Surface</u>	<u>20</u>
<u>loose lime rock</u>	<u>20</u>	<u>45</u>
<u>lime rock</u>	<u>45</u>	<u>90</u>
<u>sand rock</u>	<u>90</u>	<u>120</u>

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>78</u>	<u>6</u>	<u>78</u>	<u>120</u>

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel PE 18197 PSI 1200 A-120 USP puller adaptor</u>	<u>Surface</u>	<u>78</u>

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>clay</u>	<u>Surface</u>	<u>8</u>
<u>cement</u>	<u>8</u>	<u>78</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-air w/drilling mud Rotary-w/drilling mud Rotary-hammer w/drilling mud & air Rotary-hammer & air Reverse Rotary Jetting with Air Water

Well construction completed on 6-23 1986

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 8 GPM Well is terminated 12 inches above final grade below

Depth from surface to normal water level 80 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 84 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 6-24 1986

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Donald C. Kirschbaum Registered Well Driller Business Name and Complete Mailing Address Dons Well Drilling Box 75 Rt 4 Box 75 Boscobel Wis 53805