

OCT 25 1976

NOTE:

White Copy - Division's Copy
Green Copy - Driller's Copy
Yellow Copy - Owner's Copy

1. COUNTY Crawford		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City		Name Eastman	
2. LOCATION OR - Grid or Street No. SW 31 8N 7W AND - If available subdivision name, lot & block No. (6)		3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING		CHECK (✓) ONE Dennis Movel ADDRESS RFD POST OFFICE Prairie du Chien, WI 53821	
4. Distance in feet from well to nearest: (Record answer in appropriate block)		Building 15'		Sanitary Bldg. Drain C.I. Other	
San. Storm C.I. Other		Foundation Drain Connected to: Sewer Clearwater Dr. Sewage Sump Clearwater Sump		Sanitary Bldg. Sewer C.I. Other	
Privy Pet Waste Pit		Pit: Nonconforming Existing Well Pump Tank		Subsurface Pumproom Nonconforming Existing	
Temporary Manure Stack		Watertight Liquid Manure Tank		Solid Manure Storage Structure	
Subsurface Gasoline or Oil Tank		Waste Pond or Land Disposal Unit (Specify Type)		Other (Give Description)	
5. Well is intended to supply water for: Country Home		9. FORMATIONS			
6. DRILLHOLE		Dia. (in.)		From (ft.) To (ft.)	
10		0 Surface		173 200	
7. CASING, LINER, CURBING AND SCREEN		Dia. (in.)		From (ft.) To (ft.)	
6		P.E. New Black Steel A. 53		0 Surface 173	
		Valley Steel 1897			
		Pitless Adapter			
8. GROUT OR OTHER SEALING MATERIAL		Kind		From (ft.) To (ft.)	
Clay		Surface		7	
Cement		7		173	
10. TYPE OF DRILLING MACHINE USED		<input type="checkbox"/> Cable Tool <input type="checkbox"/> Rotary-air w/drilling mud <input type="checkbox"/> Rotary-w/drilling mud <input type="checkbox"/> Rotary-hammer w/drilling mud & air <input checked="" type="checkbox"/> Rotary-hammer & air <input type="checkbox"/> Reverse Rotary <input type="checkbox"/> Jetting with Air Water			
11. MISCELLANEOUS DATA		Well construction completed on Oct 1 1976			
Yield Test: 3 Hrs. at 4 GPM		Well is terminated 10 inches <input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below			
Depth from surface to normal water level 160 Ft.		Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
Depth of water level when pumping 172 Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
Water sample sent to Madison		laboratory on Oct 18 1976			

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature **653**
Kenneth Coplan Registered Well Driller
Complete Mail Address **R3, Box 84 - Boscobel, WI 53805**