

WELL CONSTRUCTOR'S REPORT

Well-6

AUG 3 1971

JUL 23 1971

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE Town Village City NAME Eastman

2. LOCATION (Number and Street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.)
NE 1/4 of Sec. 32 T8N R6W

3. OWNER AT TIME OF DRILLING Harold Shulka

4. OWNER'S COMPLETE MAIL ADDRESS RFD1 Box 361 Prairie du Chien, Wis. 53821

5. Distance in feet from well to nearest: (Record answer in appropriate block)

| | | | | | | | | |
|-----------------|---------------|--------------|------------------|-------------------------|-----------------|-------------|--------------------------|------|
| BUILDING C.I. # | SANITARY TILE | SEWER C.I. # | FLOOR DRAIN TILE | FOUNDATION DRAIN C.I. # | SEWER CONNECTED | INDEPENDENT | WASTE WATER DRAIN C.I. # | TILE |
| 58' | 25' | | 25' | | | | | |

| | | | | | | | | | |
|--------------------------|------|-------------|-------|-------------|------------------|------|------|----------------|-----------|
| CLEAR WATER DRAIN C.I. # | TILE | SEPTIC TANK | PRIVY | SEEPAGE PIT | ABSORPTION FIELD | BARN | SILO | ABANDONED WELL | SINK HOLE |
| | | 80' | | | 85' | | | | |

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

6. Well is intended to supply water for: Country Home

| 7. DRILLHOLE | | | 10. FORMATIONS | | | | | |
|--------------|------------|----------|----------------|------------|----------|----------------|------------|----------|
| Dia. (in.) | From (ft.) | To (ft.) | Dia. (in.) | From (ft.) | To (ft.) | Kind | From (ft.) | To (ft.) |
| 10 | Surface | 54 | 6 | 54 | 54 | Clay | Surface | 30 |
| | | | | | | limestone | 30 | 140 |
| | | | | | | hard sandstone | 140 | 300 |
| | | | | | | limestone | 300 | 420 |
| | | | | | | hard sandstone | 420 | 540 |

| 8. CASING, LINER, CURBING, AND SCREEN | | | |
|---------------------------------------|---------------------------------|------------|----------|
| Dia. (in.) | Kind and Weight | From (ft.) | To (ft.) |
| 6 | new black steel plain end 19.18 | Surface | 54 |

| 9. GROUT OR OTHER SEALING MATERIAL | | |
|------------------------------------|------------|----------|
| Kind | From (ft.) | To (ft.) |
| Clay | Surface | 30 |
| Cement | 30 | 54 |

11. MISCELLANEOUS DATA

Yield test: 4 Hrs. at 12 GPM

Well construction completed on 7-12- 1971

Well is terminated 10 inches above below final grade

Depth from surface to normal water level 460 ft. Well disinfected upon completion Yes No

Depth to water level when pumping 472 ft. Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on: 7-20- 1971

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumphrooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Coplan Registered Well Driller COMPLETE MAIL ADDRESS R3 Box 84 Breckon, Wis. 53805

Please do not write in space below

| | | | | |
|------------------------------------|---------------|---------------|-----------|---------|
| COLIFORM TEST RESULT <u>659</u> | GAS - 24 HRS. | GAS - 48 HRS. | CONFIRMED | REMARKS |
|------------------------------------|---------------|---------------|-----------|---------|