

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Eastman

2. LOCATION NW of NW Section 11 Township 8N Range 5W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE Don Noel

OR - Grid or Street No. Street or Road Name ADDRESS

AND - If available subdivision name, lot & block No. POST OFFICE Stuben Wi ZIP CODE 54657

4. Distance in feet from well to nearest: (Record answer in appropriate block)

Building	Sanitary Bldg. Drain	Sanitary Bldg. Sewer	Floor Drain Connected To:	Storm Bldg. Drain	Storm Bldg. Sewer
<u>85'</u>	C.I. Other	C.I. Other	C.I. Sewer Other Sewer	C.I. Other	C.I. Other
Street Sewer	Other Sewers	Foundation Drain Connected to:	Sewage Sump	Clearwater Sump	Septic Tank
San. Storm C.I. Other	Sewer Clearwater Dr.	Sewage Sump Clearwater Sump	C.I. Other	Clearwater Sump	Septic Tank Holding Tank
Privy Pet Waste Pit	Pit: Nonconforming Existing	Subsurface Pumproom	Barn Gutter	Animal Barn Pen	Animal Yard
Well Pump Tank	Nonconforming Existing	Nonconforming Existing	160'	180'	70'
Temporary Manure Stack or Platform	Watertight Liquid Manure Tank or Basin	Manure Pressure Pipe	Subsurface Gasoline or Oil Tank	Waste Pond or Land Disposal Unit (Specify Type)	Manure Storage Basin
					Concrete Floor Only Concrete Floor and Partial Concrete Walls

5. Well is intended to supply water for: Farm

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
<u>10</u>	<u>0</u> Surface	<u>63</u>	<u>6</u>	<u>63</u>	<u>420</u>

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel PE 18.97</u>	<u>0</u> Surface	<u>63</u>
	<u>A-53 Valley Steel</u>		
	<u>Pitless adaptor</u>		

9. FORMATIONS

Kind	From (ft.)	To (ft.)
<u>clay + rock</u>	<u>0</u> Surface	<u>35</u>
<u>lime rock</u>	<u>35</u>	<u>210</u>
<u>sand rock</u>	<u>210</u>	<u>325</u>
<u>lime rock</u>	<u>325</u>	<u>420</u>

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>clay cement</u>	<u>0</u> Surface	<u>63</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with

Rotary-air w/drilling mud Rotary-hammer & air Air

Rotary-w/drilling mud Reverse Rotary Water

Well construction completed on 11-4 19 82

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 8 GPM Well is terminated 12 inches above below final grade

Depth from surface to normal water level 340 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 344 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 11-29 19 82

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Donald C. Kischbaum Registered Well Driller Business Name and Complete Mailing Address Don's Well Drilling Box 75
Madison WI 53805