

White Copy - Division's Copy
Green Copy - Driller's Copy
Yellow Copy - Owner's Copy

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Eastman

2. LOCATION 1/4 Section SE Section 35 Township 8N Range 6W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE Le Roy Lenzendorf

OR - Grid or Street No. Street Name ADDRESS R1

AND - If available subdivision name, lot & block No. POST OFFICE Prairie du Chien, Wis. 53821

4. Distance in feet from well to nearest: (Record answer in appropriate block)

Building	Sanitary Bldg. Drain	Sanitary Bldg. Sewer	Floor Drain Connected To:	Storm Bldg. Drain	Storm Bldg. Sewer
<u>10'</u>	C.I. Other	C.I. Other	C.I. Sewer Other Sewer	C.I. Other	C.I. Other

Street Sewer Other Sewers Foundation Drain Connected to: Sewage Sump Clearwater Sump Septic Tank Holding Tank Sewage Absorption Unit 75'

San.	Storm	C.I.	Other	Sewer	Sewage Sump	C.I.	Other	Clearwater Sump	Septic Tank	Holding Tank	Sewage Absorption Unit
				Clearwater Dr.	Clearwater Sump			<u>60'</u>			Seepage Pit Seepage Bed Seepage Trench

Privy Pet Waste Pit Pit: Nonconforming Existing Subsurface Pump Room Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Country home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>210</u>	<u>6</u>	<u>210</u>	<u>470</u>

9. FORMATIONS

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>30</u>
<u>limestone</u>	<u>30</u>	<u>112</u>
<u>hard shalestone</u>	<u>112</u>	<u>200</u>
<u>sandstone</u>	<u>200</u>	<u>250</u>
<u>limestone</u>	<u>250</u>	<u>470</u>

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel P.E. 18.97 A-53</u>	<u>Surface</u>	<u>210</u>
	<u>Valley Steel</u>		
	<u>Pitless adaptor</u>		

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>8</u>
<u>Cement</u>	<u>8</u>	<u>210</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-air w/drilling mud Rotary-w/drilling mud Rotary-hammer w/drilling mud & air Rotary-hammer & air Reverse Rotary Jetting with Air Water

Well construction completed on 8-9-1977

11. MISCELLANEOUS DATA

Yield Test: 4 Hrs. at 5 GPM

Depth from surface to normal water level 380 Ft.

Depth of water level when pumping 396 Ft. Stabilized Yes No

Well is terminated 10 inches above below final grade

Well disinfected upon completion Yes No

Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 8-15-1977

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Copron Registered Well Driller 662

Complete Mail Address Boocobel, Wis. R3 Box 84 53805