

WELL CONSTRUCTOR'S REPORT

Well-6

WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

CR-163-U
STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

1. COUNTY Crawford CHECK ONE Town Village City NAME Eastman

2. LOCATION (Number and Street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.)
SE 1/4 of Sec. 35 T 8 N R 6 W

3. OWNER AT TIME OF DRILLING Matt Lechner

4. OWNER'S COMPLETE MAIL ADDRESS R1 Hauzeka, Wis.

5. Distance in feet from well to nearest: (Record answer in appropriate block)		BUILDING C.I.	SANITARY SEWER TILE	FLOOR DRAIN C.I.	FOUNDATION DRAIN SEWER CONNECTED	FOUNDATION DRAIN INDEPENDENT	WASTE WATER DRAIN C.I.	WASTE WATER DRAIN TILE
		8'	12'	12'				
CLEAR WATER DRAIN C.I.	SEPTIC TANK TILE	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILLO	ABANDONED WELL	SINK HOLE
	60'		80'		200'		100'	

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

6. Well is intended to supply water for: Farm home

7. DRILLHOLE						10. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	114	6	114	200	Clay	Surface	15
						Clay & Rock	15	45
						limestone	45	200

8. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6	new black steel plain end 19.18	Surface	114

9. GROUT OR OTHER SEALING MATERIAL		
Kind	From (ft.)	To (ft.)
Clay	Surface	15
Cement	15	114

11. MISCELLANEOUS DATA

Yield test: 3 Hrs. at 12 GPM

Well construction completed on 9-12-1969

Well is terminated 10 inches above below final grade

Depth from surface to normal water level 150 ft. Well disinfected upon completion Yes No

Depth to water level when pumping 160 ft. Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on: 10-28-1969

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumphrooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Coplan Registered Well Driller COMPLETE MAIL ADDRESS R3 Box 84 Boscobel Wis., 53805

Please do not write in space below

COLIFORM TEST RESULT <u>663</u>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
------------------------------------	---------------	---------------	-----------	---------