

APR 20 1978

NOTE:

White Copy - Division's Copy
Green Copy - Driller's Copy
Yellow Copy - Owner's Copy

WELL CONSTRUCTOR'S REPORT
Form 3300-15 Rev. 12-76

MAY 08 1978

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Eastman

2. LOCATION NW Section 36 Township 8N Range 6W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE
OR - Grid of Street No. Street Name ADDRESS John Chesk

AND - If available subdivision name, lot & block No. POST OFFICE Eastman Wis

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 30 Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Other Sewers C.I. Other Foundation Drain Connected to: Sewer Sewage Sump Clearwater Dr. Sewage Sump Clearwater Sump Sewage Absorption Unit Seepage Pit Seepage Bed Seepage Trench 80

Privy Ret Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: farm

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10	Surface	316			
6	316	544			

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
6"	New Steel T & C 19.45 A-53 Youngstown	Surface	316

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
Cement grout	Surface	316

9. FORMATIONS

Kind	From (ft.)	To (ft.)
Clay	Surface	6
Galena lime	6	106
gray rock	106	117
Blue rock	117	127
Red rock	127	140
trenton lime	140	195
St Peter sandstone	195	285
shale	285	293
may lime	293	544

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with Air Water

Rotary-air w/drilling mud Rotary-hammer & air

Rotary-w/drilling mud Reverse Rotary

Well construction completed on Feb 10 1978

11. MISCELLANEOUS DATA

Yield Test: 2 Hrs. at 25 GPM Well is terminated 8 inches above final grade below

Depth from surface to normal water level 400 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 420 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on Mar 23 1978

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Ralph J. Faherty Registered Well Driller Lololo Complete Mail Address FAHERTY DRILLING CO., INC.
1120 Broadway
PLATTEVILLE, WISCONSIN 53818