

MAR 6 1978

State of Wisconsin
Department of Natural Resources
Box 7921
Madison, Wisconsin 53707

NOTE:
White Copy - Division's Copy
Green Copy - Driller's Copy
Yellow Copy - Owner's Copy

WELL CONSTRUCTOR'S REPORT
Form 3300-15 Rev. 12-76

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Castman

2. LOCATION NW 36 Township 5N Range 6W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE
OR - Grid or Street No. Street Name 8 ADDRESS John Chest

AND - If available subdivision name, lot & block No. POST OFFICE Waupesa

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 30

Sanitary Bldg. Drain		Sanitary Bldg. Sewer		Floor Drain Connected To:		Storm Bldg. Drain		Storm Bldg. Sewer	
C.I.	Other	C.I.	Other	C.I. Sewer	Other Sewer	C.I.	Other	C.I.	Other

Street Sewer		Other Sewers		Foundation Drain Connected to:		Sewage Sump		Clearwater Sump		Septic Tank		Holding Tank		Sewage Absorption Unit	
San.	Storm	C.I.	Other	Sewer	Clearwater Dr.	Sewage Sump	Clearwater Sump	C.I.	Other					Seepage Pit	
														Seepage Bed	<u>80</u>
														Seepage Trench	

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank

Subsurface Pump Room Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Farm

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>316</u>			
<u>6</u>	<u>316</u>	<u>549</u>			

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
<u>6"</u>	<u>New Steel T & C 19.45</u>	<u>Surface</u>	<u>316</u>
	<u>A-5 3 youngstown</u>		

9. FORMATIONS

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>6</u>
<u>galena lime</u>	<u>6</u>	<u>106</u>
<u>gray rock</u>	<u>106</u>	<u>117</u>
<u>Blue rock</u>	<u>117</u>	<u>127</u>
<u>Oil rock</u>	<u>127</u>	<u>140</u>
<u>Trenton lime</u>	<u>140</u>	<u>195</u>
<u>St Peter</u>	<u>195</u>	<u>285</u>
<u>Shale</u>	<u>285</u>	<u>293</u>
<u>map lime</u>	<u>293</u>	<u>549</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with Air Water

Rotary-air w/drilling mud Rotary-hammer & air Reverse Rotary

Rotary-w/drilling mud

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Cement</u>	<u>Surface</u>	<u>316</u>

Well construction completed on Feb 10 1978

11. MISCELLANEOUS DATA

Yield Test: 2 Hrs. at 25 GPM Well is terminated 8 inches above final grade below

Depth from surface to normal water level 420 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 400 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on Feb 16 1978

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Ralph Faherty Registered Well Driller Complete Mail Address FAHERTY DRILLING CO., INC.
1120 Broadway
PLATTEVILLE, WISCONSIN 53818

6667