

WELL CONSTRUCTOR'S REPORT TO WISCONSIN STATE BOARD OF HEALTH

See Instructions on Reverse Side

- 1. County Crawford Town  Prairie du Chien  
 Village  City  Check one and give name
- 2. Location Government Lot No. 3 - Section 36 - Town No. 8 - Range 7 West  
 Name of street and number of premise or Section, Town and Range numbers
- 3. Owner  or Agent  Harold Shulka  
 Name of individual, partnership or firm
- 4. Mail Address Prairie du Chien, Wis.  
 Complete address required
- 5. From well to nearest: Building 20 ft; sewer \_\_\_\_\_ ft; drain \_\_\_\_\_ ft; septic tank 60 ft;  
 dry well or filter bed 75 ft; abandoned well \_\_\_\_\_ ft.
- 6. Well is intended to supply water for: Tavern

7. DRILLHOLE:

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
<u>10"</u>	<u>0</u>	<u>65</u>	<u>6"</u>	<u>65</u>	<u>99</u>

8. CASING AND LINER PIPE OR CURBING:

Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
<u>6"</u>	<u>Standard 6"</u>	<u>0</u>	<u>66</u>

9. GROUT:

Kind	From (ft.)	To (ft.)
<u>Cement</u>	<u>0</u>	<u>66</u>

11. MISCELLANEOUS DATA:

Yield test: 3 Hrs. at 15 GPM.  
 Depth from surface to water-level: 20 ft.  
 Water-level when pumping: 30 ft.  
 Water sample was sent to the state laboratory at:  
Madison on Sept 20 1960  
 City

10. FORMATIONS:

Kind	From (ft.)	To (ft.)
<u>Gordan sandstone</u>	<u>0</u>	<u>99</u>
<b>RECEIVED</b>		
SEP 21 1960		
<b>SANITARY ENGINEERING</b>		

Construction of the well was completed on:

Sept. 14 1960

The well is terminated 14" inches  
 above, below  the permanent ground surface.

Was the well disinfected upon completion?

Yes  No \_\_\_\_\_

Was the well sealed watertight upon completion?

Yes  No \_\_\_\_\_

Signature Duane Lubbers  
 Registered Well Driller

Parkersburg, Iowa  
 Complete Mail Address

Please do not write in space below

Rec'd \_\_\_\_\_ No. \_\_\_\_\_  
 Ans'd \_\_\_\_\_  
 Interpretation \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

10 ml 10 ml 10 ml 10 ml 10 ml  
 Gas—24 hrs. \_\_\_\_\_  
 48 hrs. \_\_\_\_\_  
 Confirm \_\_\_\_\_  
 B. Coli \_\_\_\_\_  
 Examiner \_\_\_\_\_