

WELL CONSTRUCTOR'S REPORT

DEPARTMENT OF RESOURCE DEVELOPMENT

1. COUNTY Crawford CHECK ONE Town Village City NAME Prairie Du Chien SEP 1970

2. LOCATION (Number and Street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.)
Port & 400 Lots 1, 2 and 3 in Sec. 36 - Town 8N - Range 7W

3. OWNER AT TIME OF DRILLING
Port & 400 Lots 1, 2 and 3 in Leonard W. Hungenber

4. OWNER'S COMPLETE MAIL ADDRESS
Route No. 1 - Box 367 Prairie Du Chien, Wis.

5. Distance in feet from well to nearest:
 (Record answer in appropriate block)

BUILDING	SANITARY SEWER	FLOOR DRAIN	FOUNDATION DRAIN	WASTE WATER DRAIN
C. I.	TILE	C. I.	TILE	C. I.
			SEWER CONNECTED	INDEPENDENT
	90			

CLEAR WATER DRAIN	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILLO	ABANDONED WELL	SINK HOLE
C. I.	TILE							
	75		125					

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)
None

6. Well is intended to supply water for:
Vacation Cottage

7. DRILLHOLE			10. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
6	Surface	130			

8. CASING, LINER, CURBING, AND SCREEN				10. FORMATIONS	
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)	Kind	To (ft.)
6	Steel-new casing 19.45 Per ft. with drive shoe Plain end	Surface	115	Drift	20'
				Sand and gravel	95
				Soft Jordan sand	115
				Hard Jordan sand	130

9. GROUT OR OTHER SEALING MATERIAL		
Kind	From (ft.)	To (ft.)
	Surface	

11. MISCELLANEOUS DATA		
Yield test:	4	Hrs. at 15 GPM
Depth from surface to normal water level	15	ft.
Depth to water level when pumping	20	ft.

Well construction completed on Oct. 22 1969

Well is terminated 30 inches above below final grade

Well disinfected upon completion Yes No

Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on: 8-12 1970

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumphrooms, access pits, etc., should be given on reverse side.

SIGNATURE Leuis Harris Registered Well Driller COMPLETE MAIL ADDRESS 327 N. Main St. Prairie Du Chien, Wis.

Please do not write in space below

COLIFORM TEST RESULT	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
6669				