

NOTE:

White Copy - Division's Copy
 Green Copy - Driller's Copy
 Yellow Copy - Owner's Copy

JAN 16 1981
 DEC 29 1980

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Eastman

2. LOCATION NW Section 15 Township 8N Range 5W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE Lennie Davidson

OR - Grid or Street No. Street Name ADDRESS Eastman R1

AND - If available subdivision name, lot & block No. POST OFFICE WI 54626

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 8'

Sanitary Bldg. Drain		Sanitary Bldg. Sewer		Floor Drain Connected To:		Storm Bldg. Drain		Storm Bldg. Sewer	
C.I.	Other	C.I.	Other	C.I. Sewer	Other Sewer	C.I.	Other	C.I.	Other

Street Sewer: San. Storm C.I. Other
 Other Sewers: C.I. Other
 Foundation Drain Connected to: Sewer Clearwater Dr. Sewage Sump Clearwater Sump
 Sewage Sump: C.I. Other
 Clearwater Sump
 Septic Tank: 50'
 Holding Tank
 Sewage Absorption Unit: 60'
 Seepage Pit
 Seepage Bed
 Seepage Trench

Privy: Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank
 Subsurface Pumproom: Nonconforming Existing
 Barn Gutter
 Animal Barn Pen
 Animal Yard
 Silo With Pit
 Glass Lined Storage Facility
 Silo w/o Pit
 Earthen Silage Storage Trench Or Pit

Temporary Manure Stack
 Watertight Liquid Manure Tank
 Solid Manure Storage Structure
 Subsurface Gasoline or Oil Tank
 Waste Pond or Land Disposal Unit (Specify Type)
 Other (Give Description)

5. Well is intended to supply water for: Trailer home

9. FORMATIONS

Kind	From (ft.)	To (ft.)
<u>Clay & stone</u>	<u>Surface</u>	<u>25</u>
<u>hard sandstone</u>	<u>25</u>	<u>68</u>
<u>limestone</u>	<u>68</u>	<u>80</u>

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>45</u>	<u>6</u>	<u>45</u>	<u>80</u>

7. CASING, LINER, CURBING AND SCREEN
 Material, Weight, Specification & Method of Assembly

Dia. (in.)	From (ft.)	To (ft.)
<u>6</u>	<u>Surface</u>	<u>45</u>

new black steel P.E. 18.97 A-53
Keystone Pipe
Pitless adapter

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>8</u>
<u>Cement</u>	<u>8</u>	<u>45</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with Air Water

Rotary-air w/drilling mud Rotary-hammer & air

Rotary-w/drilling mud Reverse Rotary

Well construction completed on 12-18-1980

11. MISCELLANEOUS DATA

Yield Test: 4 Hrs. at 5 GPM

Well is terminated 8 inches above below final grade

Depth from surface to normal water level 25 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 42 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 12-22-1980

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Coplan Registered Well Driller Complete Mail Address Boscobel, WI. R2 Box 4 53805