

WELL CONSTRUCTOR'S REPORT  
FORM 3300-15

OCT 5 1973  
STATE OF WISCONSIN  
DEPARTMENT OF NATURAL RESOURCES  
Box 450  
Madison, Wisconsin 53701

**NOTE**  
WHITE COPY - DIVISION'S COPY  
GREEN COPY - DRILLER'S COPY  
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE  Town  Village  City NAME Scott

2. LOCATION - 1/4 Section NW Section 1 Township 9N Range 3W

OR - Grid or street no. Street name ADDRESS R1

AND - If available subdivision name, lot & block no. POST OFFICE Blue River, Wis., 53518

3. OWNER AT TIME OF DRILLING Russell Darling

4. Distance in feet from well to nearest:

BUILDING	SANITARY SEWER C.I.	SEWER TILE	FLOOR DRAIN C.I.	FLOOR DRAIN TILE	FOUNDATION DRAIN SEWER CONNECTED	FOUNDATION DRAIN INDEPENDENT	WASTE WATER DRAIN C.I.	WASTE WATER DRAIN TILE
<u>10'</u>	<u>18'</u>		<u>18'</u>					

(Record answer in appropriate block)

CLEAR WATER DRAIN C.I.	CLEAR WATER DRAIN TILE	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILLO	ABANDONED WELL	SINK HOLE
		<u>60'</u>			<u>70'</u>				

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Country home

6. DRILLHOLE						9. FORMATIONS			
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
<u>10</u>	<u>Surface</u>	<u>64</u>	<u>6</u>	<u>64</u>	<u>115</u>	<u>Clay</u>	<u>Surface</u>	<u>12</u>	<u>12</u>
						<u>soft shalestone</u>	<u>12</u>	<u>50</u>	
						<u>hard shalestone</u>	<u>50</u>	<u>80</u>	
						<u>sandstone</u>	<u>80</u>	<u>115</u>	

7. CASING, LINER, CURBING, AND SCREEN

Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel plain end 19.18</u>	<u>Surface</u>	<u>64</u>

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>12</u>
<u>Cement</u>	<u>12</u>	<u>64</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool  Direct Rotary  Reverse Rotary

Rotary - air w/drilling mud  Rotary - hammer with drilling mud & air  Jetting with  Air  Water

Well construction completed on 9-5-1973

11. MISCELLANEOUS DATA

Yield test: 3 Hrs. at 8 GPM

Well is terminated 8 inches  above  below final grade

Depth from surface to normal water level 68 ft. Well disinfected upon completion  Yes  No

Depth to water level when pumping 70 ft. Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on: 10-2-1973

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Coplan Registered Well Driller COMPLETE MAIL ADDRESS Roseobel, Wis. R3 Box 84 53805

Please do not write in space below

COLIFORM TEST RESULT <u>671</u>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS <input checked="" type="checkbox"/>
------------------------------------	---------------	---------------	-----------	---

REV. 3-71