

WELL CONSTRUCTOR'S REPORT  
FORM 3300-15

JUL 31 1973

NOTE

WHITE COPY - DIVISION'S COPY  
GREEN COPY - DRILLER'S COPY  
YELLOW COPY - OWNER'S COPY

STATE OF WISCONSIN  
DEPARTMENT OF NATURAL RESOURCES  
Box 450  
Madison, Wisconsin 53701

1. COUNTY Crawford CHECK ONE  Town  Village  City NAME Scott

2. LOCATION - 1/4 Section SE Section 3 Township 9N Range 3W 3. OWNER AT TIME OF DRILLING L. N. Christensen

OR - Grid or street no. Street name ADDRESS R2

AND - If available subdivision name, lot & block no. POST OFFICE Gayle Mills, Wis., 54631

4. Distance in feet from well to nearest:

BUILDING	SANITARY SEWER	FLOOR DRAIN	FOUNDATION DRAIN	WASTE WATER DRAIN
C. I.	TILE	C. I.	SEWER CONNECTED INDEPENDENT	C. I. TILE

(Record answer in appropriate block)

CLEAR WATER DRAIN	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILLO	ABANDONED WELL	SINK HOLE
C. I. TILE								

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Cattle in Pasture

6. DRILLHOLE						9. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	40	6	40	100	Clay	Surface	25
						limestone	25	60
						sandstone	60	100

7. CASING, LINER, CURBING, AND SCREEN

Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6	new black steel plain end 19.18	Surface	40

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
Clay	Surface	25
Cement	25	40

10. TYPE OF DRILLING MACHINE USED

Cable Tool  Direct Rotary  Reverse Rotary

Rotary - air w/drilling mud  Rotary - hammer with drilling mud & air  Jetting with  Air  Water

11. MISCELLANEOUS DATA

Yield test: 2 Hrs. at 8 GPM

Depth from surface to normal water level 20 ft.

Depth to water level when pumping 22 ft.

Well construction completed on 7-19-1973

Well is terminated 12 inches  above  below final grade

Well disinfected upon completion  Yes  No

Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on: 7-26-1973

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Coyran Registered Well Driller COMPLETE MAIL ADDRESS Boscobel, Wis., 53805

R3 Box 84

Please do not write in space below

COLIFORM TEST RESULT <u>674</u>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
------------------------------------	---------------	---------------	-----------	---------

REV. 3-71