

WELL CONSTRUCTOR'S REPORT  
FORM 3300-15

MAY 09 1974

STATE OF WISCONSIN  
DEPARTMENT OF NATURAL RESOURCES  
Box 450  
Madison, Wisconsin 53701

NOTE

WHITE COPY - DIVISION'S COPY  
GREEN COPY - DRILLER'S COPY  
YELLOW COPY - OWNER'S COPY

1. COUNTY <u>Crawford</u>		CHECK ONE <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City		NAME <u>Scott</u>	
2. LOCATION - 1/4 Section <u>SW</u> Section <u>7</u> Township <u>9N</u> Range <u>3W</u>		3. OWNER AT TIME OF DRILLING <u>Carl Zimpel</u>			
OR - Grid or street no.		Street name		ADDRESS <u>R7D</u>	
AND - If available subdivision name, lot & block no.		POST OFFICE		<u>Haye Mills 54631</u> <del>Soldier Grove, Wis 54655</del>	
4. Distance in feet from well to nearest: (Record answer in appropriate block)		BUILDING C. I.	SANITARY SEWER TILE	FLOOR DRAIN C. I.	FOUNDATION DRAIN SEWER CONNECTED INDEPENDENT
		<u>150'</u>	<u>160'</u>		
CLEAR WATER DRAIN C. I.	SEPTIC TANK TILE	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN SILO
	<u>180'</u>			<u>180'</u>	<u>75'</u>
OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)					

5. Well is intended to supply water for: Country home

6. DRILLHOLE						9. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>40</u>	<u>6</u>	<u>40</u>	<del>40</del> <u>60</u>	<u>Clay</u>	<u>Surface</u>	<u>20</u>
						<u>Clay &amp; sand</u>	<u>20</u>	<u>30</u>
						<u>hard shalestone</u>	<u>30</u>	<u>60</u>

7. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel plain end 19.18</u>	<u>Surface</u>	<u>40</u>

8. GROUT OR OTHER SEALING MATERIAL		
Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>20</u>
<u>Cement</u>	<u>20</u>	<u>40</u>

10. TYPE OF DRILLING MACHINE USED		
<input type="checkbox"/> Cable Tool	<input type="checkbox"/> Direct Rotary	<input type="checkbox"/> Reverse Rotary
<input type="checkbox"/> Rotary - air w/drilling mud	<input checked="" type="checkbox"/> Rotary - hammer with drilling mud & air	<input type="checkbox"/> Jetting with <input type="checkbox"/> Air <input type="checkbox"/> Water
Well construction completed on <u>4-12-1974</u>		

11. MISCELLANEOUS DATA	
Yield test: <u>3 Hrs. at</u>	<u>5 GPM</u>
Depth from surface to normal water level	<u>15</u> ft.
Depth to water level when pumping	<u>18</u> ft.

Well is terminated <u>10</u> inches <input checked="" type="checkbox"/> above <input type="checkbox"/> below final grade
Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No

Water sample sent to Madison laboratory on: 5-6-1974

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE <u>Kenneth Coplan</u> Registered Well Driller	COMPLETE MAIL ADDRESS <u>R3 Box 84 Boscobel Wis., 53805</u>
---	--

COLIFORM TEST RESULT <u>680</u>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
------------------------------------	---------------	---------------	-----------	---------