

WELL CONSTRUCTOR'S REPORT
FORM 3300-15

DEC 2 1974

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

NOTE
WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE Town Village City NAME Scott

2. LOCATION - 1/4 Section NE Section 8 Township 9N Range 3W
OR - Grid or street no. Street name
3. OWNER AT TIME OF DRILLING Mr. Paul Walton
ADDRESS R7D

AND - If available subdivision name, lot & block no. POST OFFICE Gays Mills, Wis. 54631

4. Distance in feet from well to nearest:
(Record answer in appropriate block)

BUILDING C. I.	SANITARY SEWER TILE	FLOOR DRAIN C. I.	TILE	FOUNDATION DRAIN SEWER CONNECTED	INDEPENDENT	WASTE WATER DRAIN C. I.	TILE
	<u>20'</u>	<u>28'</u>					

CLEAR WATER DRAIN C. I.	TILE	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO	ABANDONED WELL	SINK HOLE
		<u>60'</u>		<u>80'</u>		<u>400'</u>			

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Country home

6. DRILLHOLE						9. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>214</u>	<u>6</u>	<u>214</u>	<u>255</u>	<u>Clay</u>	<u>Surface</u>	<u>30</u>
						<u>limestone</u>	<u>30</u>	<u>150</u>
						<u>soft sandstone</u>	<u>150</u>	<u>200</u>
						<u>hard sandstone</u>	<u>200</u>	<u>240</u>
						<u>hard shalestone</u>	<u>240</u>	<u>255</u>

7. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel plain ends 18.97</u>	<u>Surface</u>	<u>214</u>

8. GROUT OR OTHER SEALING MATERIAL			10. TYPE OF DRILLING MACHINE USED		
Kind	From (ft.)	To (ft.)	<input type="checkbox"/> Cable Tool	<input type="checkbox"/> Direct Rotary	<input type="checkbox"/> Reverse Rotary
<u>Clay</u>	<u>Surface</u>	<u>30</u>	<input type="checkbox"/> Rotary - air w/drilling mud	<input checked="" type="checkbox"/> Rotary - hammer with drilling mud & air	<input type="checkbox"/> Jetting with <input type="checkbox"/> Air <input type="checkbox"/> Water
<u>Cement</u>	<u>30</u>	<u>214</u>	Well construction completed on <u>10-18</u> 19 <u>74</u>		

11. MISCELLANEOUS DATA		Well is terminated		Well disinfected upon completion		Well sealed watertight upon completion		
Yield test:	<u>3</u> Hrs. at <u>6</u> GPM	<u>12</u> inches	<input checked="" type="checkbox"/> above	<input type="checkbox"/> below	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No
Depth from surface to normal water level	<u>198</u> ft.							
Depth to water level when pumping	<u>205</u> ft.							

Water sample sent to Madison laboratory on: 11-25- 1974

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Copian Registered Well Driller COMPLETE MAIL ADDRESS Boscobel R3 Box 84 Wis., 53805

COLIFORM TEST RESULT <u>685</u>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
REV. 3-71				