

OCT 25 1976

NOTE:
 White Copy - Division's Copy
 Green Copy - Driller's Copy
 Yellow Copy - Owner's Copy

WELL CONSTRUCTOR'S REPORT
 Form 3300-15
 Rev. 10-75

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Scott

2. LOCATION ¼ Section SW Section 10 Township 9N Range 3W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE
 OR - Grid or Street No. Street Name ADDRESS RFD
 AND - If available subdivision name, lot & block No. POST OFFICE Boscobel, WI 53805

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 15' Sanitary Bldg. Drain C.I. 25' Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to: Sewage Sump Clearwater Sump Septic Tank Holding Tank Sewage Absorption Unit 90'
 San. Storm C.I. Other Sewer Sewage Sump Clearwater Dr. C.I. Other Clearwater Sump Septic Tank Holding Tank Seepage Pit Seepage Bed Seepage Trench

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Country Home 9. FORMATIONS

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>0</u> Surface	<u>30</u>
<u>Limestone</u>	<u>30</u>	<u>270</u>
<u>Sandstone</u>	<u>270</u>	<u>300</u>

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
<u>10</u>	<u>0</u> Surface	<u>76</u>	<u>6</u>	<u>76</u>	<u>300</u>

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
<u>6</u>	<u>P/E New Blacksteel A-53</u>	<u>0</u> Surface	<u>76</u>
	<u>Valley Steel 18.97</u>		
	<u>Pittler Adapter</u>		

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>0</u> Surface	<u>8</u>
<u>Cement</u>	<u>8</u>	<u>76</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with

Rotary-air w/drilling mud Rotary-hammer & air Air

Rotary-w/drilling mud Reverse Rotary Water

Well construction completed on Sept 30 19 76

11. MISCELLANEOUS DATA

Yield Test: 5 Hrs. at 6 GPM Well is terminated 12 inches above final grade below

Depth from surface to normal water level 220 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 235 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on Oct, 18 19 76

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature 689
Benneth Coplan Registered Well Driller Complete Mail Address R3, Box 84 - Boscobel, WI 53805