

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Castman WI

2. LOCATION SE 19 8N 5W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE Bud Inautsch

OR - Grid or Street No. Street or Road Name ADDRESS Box 146

AND - If available subdivision name, lot & block No. POST OFFICE Castman WI ZIP CODE

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 100'

Sanitary Bldg. Drain		Sanitary Bldg. Sewer		Floor Drain Connected To:		Storm Bldg. Drain		Storm Bldg. Sewer	
C.I.	Other	C.I.	Other	C.I. Sewer	Other Sewer	C.I.	Other	C.I.	Other

Street Sewer		Other Sewers		Foundation Drain Connected to:		Sewage Sump		Clearwater Sump	Septic Tank	Holding Tank	Sewage Absorption Unit		Manure Hopper or Retention or Pneumatic Tank
San.	Storm	C.I.	Other	Sewer	Clearwater Dr.	C.I.	Other				N/A		
											Seepage Pit	Seepage Bed	

Privy	Pet Waste Pit	Pit: Nonconforming Existing	Subsurface Pumproom	Barn Gutter	Animal Barn Pen	Animal Yard	Silo With Pit	Glass Lined Storage Facility	Silo w/o Pit	Earthen Silage Storage Trench Or Pit	Earthen Manure Basin
		Well	Nonconforming Existing		120				150		

Temporary Manure Stack or Platform	Watertight Liquid Manure Tank or Basin	Manure Pressure Pipe	Subsurface Gasoline or Oil Tank	Waste Pond or Land Disposal Unit (Specify Type)	Manure Storage Basin	Other (Describe)
					Concrete Floor Only Concrete Floor and Partial Concrete Walls	

5. Well is intended to supply water for: farm home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10	Surface	246	6	246	360

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification	From (ft.)	To (ft.)
6"	A-53 P.E. 18.97 #/ft. pitless adapter Kent Steel	Surface	246

9. FORMATIONS

Kind	From (ft.)	To (ft.)
top soil	Surface	19
limestone & clay	19	84
soft sandstone	84	117
broken limestone	117	230
hard limestone	230	360

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
clay	Surface	8
Cement	8	246

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drifting mud & air Jetting with

Rotary-air w/drilling mud Rotary-hammer & air Air

Rotary-w/drilling mud Reverse Rotary Water

Well construction completed on 9-11 1981

11. MISCELLANEOUS DATA

Yield Test: 2 Hrs. at 9 GPM Well is terminated 15 inches above final grade below

Depth from surface to normal water level 280 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 290 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 9-21 1981

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature [Signature] Registered Well Driller Business Name and Complete Mailing Address Kenneth Corplan & Sons, Inc
Rt. 2 Box 4 Boonville WI 53805