

SEP 21 1972

WELL CONSTRUCTOR'S REPORT
FORM 3300-15

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

NOTE
WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE Town Village City NAME Scott

2. LOCATION - 1/4 Section NW Section 12 Township T9N Range R3W 3. OWNER AT TIME OF DRILLING Chris Zales

OR - Grid or street no. Street name ADDRESS

AND - If available subdivision name, lot & block no. POST OFFICE Blue River, Wis.

4. Distance in feet from well to nearest:

BUILDING	SANITARY SEWER	FLOOR DRAIN	FOUNDATION DRAIN	WASTE WATER DRAIN
C. I.	TILE	C. I.	SEWER CONNECTED	INDEPENDENT
<u>60</u>				

(Record answer in appropriate block)

CLEAR WATER DRAIN	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO	ABANDONED WELL	SINK HOLE
C. I.	TILE							
	<u>140</u>							

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Home

6. DRILLHOLE						9. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>71</u>				<u>Clay</u>	<u>Surface</u>	<u>40</u>
<u>6</u>	<u>71</u>	<u>560</u>				<u>May lime</u>	<u>40</u>	<u>168</u>
7. CASING, LINER, CURBING, AND SCREEN								
Dia. (in.)	Kind and Weight		From (ft.)	To (ft.)				
<u>6</u>	<u>New Steel 74 C 19.18</u>		<u>Surface</u>	<u>71</u>		<u>Temp sandstone</u>	<u>168</u>	<u>232</u>
						<u>Temp Limestone</u>	<u>232</u>	<u>242</u>
						<u>Halesville sandstone</u>	<u>242</u>	<u>433</u>
						<u>Francon sandstone</u>	<u>433</u>	<u>560</u>

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Cement</u>	<u>Surface</u>	<u>71</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool Direct Rotary Reverse Rotary

Rotary - air w/drilling mud Rotary - hammer with drilling mud & air Jetting with Air Water

Well construction completed on 7-15 1972

11. MISCELLANEOUS DATA

Yield test: 2 Hrs. at 20 GPM

Well is terminated 8 inches above below final grade

Depth from surface to normal water level 350 ft. Well disinfected upon completion Yes No

Depth to water level when pumping 440 ft. Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on: 9/19 1972

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Ralph Faherty Registered Well Driller COMPLETE MAIL ADDRESS 1120 Broadway Platteville, Wis.

Please do not write in space below

COLIFORM TEST RESULT <u>692</u>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
------------------------------------	---------------	---------------	-----------	---------