

DEC 20 1971

WELL CONSTRUCTOR'S REPORT
FORM 3300-15

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

NOTE
WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE Town Village City NAME Scott

2. LOCATION - 1/4 Section NW Section 12 Township 9N Range 3W

OR - Grid or street no. Street name

3. OWNER AT TIME OF DRILLING Louis J. Cherbin
ADDRESS R7 D 1
POST OFFICE Blue River, Wis. 53518

4. Distance in feet from well to nearest:
(Record answer in appropriate block)

BUILDING C.I.	SANITARY C.I.	SEWER TILE	FLOOR DRAIN C.I.	FLOOR DRAIN TILE	FOUNDATION DRAIN SEWER CONNECTED	FOUNDATION DRAIN INDEPENDENT	WASTE WATER DRAIN C.I.	WASTE WATER DRAIN TILE
<u>15'</u>	<u>40'</u>		<u>40'</u>				<u>40'</u>	

CLEAR WATER DRAIN C.I.	CLEAR WATER DRAIN TILE	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO	ABANDONED WELL	SINK HOLE
		<u>60'</u>			<u>75'</u>	<u>125'</u>			

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Farm home

6. DRILLHOLE						9. FORMATIONS			
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
<u>10</u>	<u>Surface</u>	<u>60</u>	<u>6</u>	<u>60</u>	<u>120</u>	<u>Clay</u>	<u>Surface</u>	<u>10</u>	
						<u>shalestone</u>	<u>10</u>	<u>50</u>	
						<u>limestone</u>	<u>50</u>	<u>100</u>	
						<u>sandstone</u>	<u>100</u>	<u>120</u>	

8. GROUT OR OTHER SEALING MATERIAL				10. TYPE OF DRILLING MACHINE USED			
Kind	From (ft.)	To (ft.)					
<u>Clay</u>	<u>Surface</u>	<u>10</u>	<input type="checkbox"/> Cable Tool	<input type="checkbox"/> Direct Rotary	<input type="checkbox"/> Reverse Rotary	<input type="checkbox"/> Jetting with	<input type="checkbox"/> Air <input type="checkbox"/> Water
<u>Cement</u>	<u>10</u>	<u>60</u>	<input type="checkbox"/> Rotary - air w/drilling mud	<input checked="" type="checkbox"/> Rotary - hammer with drilling mud & air			

11. MISCELLANEOUS DATA

Yield test: 3 Hrs. at 12 GPM

Well construction completed on 12-2- 1971

Well is terminated 10 inches above below final grade

Depth from surface to normal water level 80 ft. Well disinfected upon completion Yes No

Depth to water level when pumping 83 ft. Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on: 12-15-1971

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Popian Registered Well Driller COMPLETE MAIL ADDRESS R3 Box 84 Boscobel, Wis., 53805

Please do not write in space below

COLIFORM TEST RESULT <u>693</u>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
------------------------------------	---------------	---------------	-----------	---------