

THIS IS A DUPLICATE COPY OF THE ONE SENT YOU ON THE 10/22/45.  
 WELL CONSTRUCTOR'S REPORT TO WISCONSIN STATE BOARD OF HEALTH  
 See Instructions on Reverse Side

1. County CRAWFORD { Town SCOTT Village T9N City SCOTT OCT 22 1947
2. Location N.W. 1/4 OF N.E. 1/4 OF SECTION #12, RANGE # 3 WEST. (9N)
3. Owner or Agent KENNETH POWELL
4. Address BLUE RIVER, WISCONSIN R. F. D. # 5.
5. From well to nearest: Building 35' ft; sewer none ft; drain        ft; septic tank        ft; dry well or filter bed        ft; abandoned well        ft.
6. Well is intended to supply water for: FARM USE AND RESIDENCE.

7. DRILLHOLE OR EXCAVATION:

Dia. (in.)	From (ft.)	To (ft.)
5"	0'	64'

8. CASING AND LINER PIPE OR CURBING:

Dia. (in.)	Kind	From (ft.)	To (ft.)
5"	BLACK STANDARD STEEL		
	CASING	0'	35'

9. GROUT:

Kind	From (ft.)	To (ft.)

10. FORMATIONS:

Kind	Thick-ness (ft.)	Total Depth (ft.)
(drilled well)		
loose sand	0'	25'
SHALE ROCK	25'	64'

11. MISCELLANEOUS DATA:

Yield test: 10 Hrs. at 4 GPM.  
 Depth from surface to water: 46 feet ft.  
 Water-level when pumping: same ft.  
 Water sample sent to laboratory at  
MADISON on OCTOBER 15th 45

Construction of the well was completed on FRIDAY OCTOBER # 12th 1945.  
 The well is terminated 14" inches (above) ~~(below)~~ the permanent grade.  
 Was the well disinfected upon completion?  
 Yes YES No         
 Was the well sealed watertight upon completion?  
 Yes YES No       

Signature H. W. BARTELS P. O. BOX 323 BOSCOBEL, WISCONSIN.  
 Registered Well Driller Complete Mail Address