

NOTE:

White Copy - Division's Copy  
 Green Copy - Driller's Copy  
 Yellow Copy - Owner's Copy

**NOV 5 1980** **OCT 22 1980**

1. COUNTY Crawford CHECK (✓) ONE:  Town  Village  City Name Bridgport

2. LOCATION 1/4 Section NW Section 5 Township 6N Range 7W 3. NAME  OWNER  AGENT AT TIME OF DRILLING CHECK (✓) ONE Dr. Smith

OR - Grid or Street No. Street Name ADDRESS R1 Box 326

AND - If available subdivision name, lot & block No. POST OFFICE Prairie du Chien, Wis.

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 30' Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to: Sewer Clearwater Dr. Sewage Sump C.I. Other Clearwater Sump Clearwater Sump Clearwater Sump Clearwater Sump Clearwater Sump Holding Tank Sewage Absorption Unit Seepage Pit Seepage Bed Seepage Trench 125'

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Trailer home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>168</u>	<u>6</u>	<u>168</u>	<u>380</u>

9. FORMATIONS

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>20</u>
<u>broken limestone</u>	<u>20</u>	<u>140</u>
<u>hard limestone</u>	<u>140</u>	<u>240</u>
<u>hard sandstone</u>	<u>240</u>	<u>360</u>
<u>limestone</u>	<u>360</u>	<u>380</u>

7. CASING, LINER, CURBING AND SCREEN  
 Material, Weight, Specification & Method of Assembly

Dia. (in.)	From (ft.)	To (ft.)
<u>6</u>	<u>Surface</u>	<u>168</u>

new black steel P.E. 18.97 A-53  
Keystone pipe  
Pitless adapter

10. TYPE OF DRILLING MACHINE USED

Cable Tool  Rotary-air w/drilling mud  Rotary-w/drilling mud  Rotary-hammer w/drilling mud & air  Rotary-hammer & air  Reverse Rotary  Jetting with  Air  Water

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>7</u>
<u>Cement</u>	<u>7</u>	<u>168</u>

Well construction completed on 9-30- 19 80

11. MISCELLANEOUS DATA

Yield Test: 4 Hrs. at 5 GPM

Depth from surface to normal water level 285 Ft.

Depth of water level when pumping 310 Ft. Stabilized  Yes  No

Well is terminated 10 inches  above  below final grade

Well disinfected upon completion  Yes  No

Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on 10-14- 19 80

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Coplan Registered Well Driller

Complete Mail Address Boscobel, Wis.  
R2 Box 4  
53805