

NOTE:

White Copy - Division's Copy
 Green Copy - Driller's Copy
 Yellow Copy - Owner's Copy

JUL 1 1980

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Eastman

2. LOCATION SW 22 8N 5W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE Sam Jesar

OR - Grid or Street No. Street Name ADDRESS R1

AND - If available subdivision name, lot & block No. POST OFFICE Wausau, WI, 53826

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 12' Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor in Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer Other Sewers Foundation Drain Connected to: Sewage Sump Clearwater Sump Septic Tank Holding Tank Sewage Absorption Unit 80'

San. Storm C.I. Other Sewer Sewage Sump Clearwater Dr. Clearwater Sump C.I. Other

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard 400' Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Farm home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	240	6	240	300	Clay	Surface	8
						broken limestone	8	225
						hard sandstone	225	300

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
6	new black steel R.E. 18.97 A-53 Kent Steel Pitless adapter	Surface	240

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
Clay	Surface	8
Cement	8	240

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drifting mud & air Jetting with Air Water

Rotary-air w/drilling mud Rotary-hammer & air

Rotary-w/drilling mud Reverse Rotary

Well construction completed on 6-7-1980

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 5 GPM Well is terminated 10 inches above final grade below

Depth from surface to normal water level 210 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 215 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 6-25-1980

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Coplan Registered Well Driller Complete Mail Address Boscobel, WI, R2 Box 4 53805