

JUL 31 1978

1. COUNTY Crawford CHECK (✓) ONE:  Town  Village  City Name Scott

2. LOCATION 1/4 Section SE Section 19 Township 9N Range 3W 3. NAME  OWNER  AGENT AT TIME OF DRILLING CHECK (✓) ONE Lee Sims  
 OR - Grid or Street No. Street Name ADDRESS R7D

AND - If available subdivision name, lot & block No. POST OFFICE Boscobel, Wis., 53805

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 15' Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to: Sewer Sewage Sump Clearwater Dr. Sewage Sump Clearwater Sump Sewage Absorption Unit Seepage Pit Seepage Bed Seepage Trench

Clearwater Sump Septic Tank Holding Tank

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Trailer home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>88</u>	<u>6</u>	<u>88</u>	<u>120</u>

9. FORMATIONS

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>10</u>
<u>broken limestone</u>	<u>10</u>	<u>30</u>
<u>soft sandstone</u>	<u>30</u>	<u>70</u>
<u>hard sandstone</u>	<u>70</u>	<u>100</u>
<u>limestone</u>	<u>100</u>	<u>120</u>

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel P.E. 18.97 A-53 Valley Steel Pitless adaptor</u>	<u>Surface</u>	<u>88</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool  Rotary-hammer w/drilling mud & air  Jetting with  Air  Water

Rotary-air w/drilling mud  Rotary-hammer & air

Rotary-w/drilling mud  Reverse Rotary

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>8</u>
<u>Cement</u>	<u>8</u>	<u>88</u>

Well construction completed on 7-3 19 78

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 5 GPM

Well is terminated 12 inches  above final grade  below

Depth from surface to normal water level 80 Ft. Well disinfected upon completion  Yes  No

Depth of water level when pumping 86 Ft. Stabilized  Yes  No Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on 7-24 19 78

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Coplan Registered Well Driller Complete Mail Address Boscobel, Wis. R3 Box 84 53805