

WELL CONSTRUCTOR'S REPORT  
FORM 3300-15

MAR 19 1974

STATE OF WISCONSIN  
DEPARTMENT OF NATURAL RESOURCES  
Box 450  
Madison, Wisconsin 53701

NOTE

WHITE COPY - DIVISION'S COPY  
GREEN COPY - DRILLER'S COPY  
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE  Town  Village  City NAME Scott

2. LOCATION - 1/4 Section SW Section 20 Township 9N Range 3W 3. OWNER AT TIME OF DRILLING Wayne Mindham

OR - Grid or street no. Street name ADDRESS R7D2

AND - If available subdivision name, lot & block no. POST OFFICE Boscobel, Wis., 53805

4. Distance in feet from well to nearest:

BUILDING	SANITARY SEWER	FLOOR DRAIN	FOUNDATION DRAIN	WASTE WATER DRAIN
C. I.	C. I.	C. I.	SEWER CONNECTED	C. I.
TILE	TILE	TILE	INDEPENDENT	TILE
<u>15'</u>	<u>40'</u>			<u>40'</u>

CLEAR WATER DRAIN	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO	ABANDONED WELL	SINK HOLE
C. I.	TILE							
	<u>80'</u>		<u>90'</u>		<u>400'</u>	<u>400'</u>	<u>30'</u>	

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Country home

6. DRILLHOLE						9. FORMATIONS			
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
<u>10</u>	<u>Surface</u>	<u>142</u>	<u>6</u>	<u>142</u>	<u>260</u>	<u>Clay</u>	<u>Surface</u>	<u>50</u>	
						<u>sand &amp; Clay</u>	<u>50</u>	<u>130</u>	
						<u>limestone</u>	<u>130</u>	<u>220</u>	
						<u>sandstone</u>	<u>220</u>	<u>260</u>	

7. CASING, LINER, CURBING, AND SCREEN

Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel plain end 19.18</u>	<u>Surface</u>	<u>142</u>

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>50</u>
<u>Cement</u>	<u>50</u>	<u>142</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool  Direct Rotary  Reverse Rotary

Rotary - air w/drilling mud  Rotary - hammer with drilling mud & air  Jetting with  Air  Water

11. MISCELLANEOUS DATA

Yield test: 3 Hrs. at 8 GPM

Depth from surface to normal water level 190 ft.

Depth to water level when pumping 225 ft.

Well construction completed on 3-8-1974

Well is terminated 10 inches  above  below final grade

Well disinfected upon completion  Yes  No

Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on: 3-14-1974

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Coprian Registered Well Driller COMPLETE MAIL ADDRESS Boscobel, Wis., 53805

R3 Box 84

Please do not write in space below

COLIFORM TEST RESULT <u>403</u>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
------------------------------------	---------------	---------------	-----------	---------