

WELL CONSTRUCTOR'S REPORT

Well-6

JUL 30 1970

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE Town Village City NAME Scott

2. LOCATION (Number and Street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.)
NE 1/4 of Sec 20 T9N R3W

3. OWNER AT TIME OF DRILLING William Young

4. OWNER'S COMPLETE MAIL ADDRESS R70 Gayle Miller, Wis., 54631

5. Distance in feet from well to nearest: (Record answer in appropriate block)

BUILDING C.I.	SANITARY SEWER TILE	FLOOR DRAIN C.I.	TILE	FOUNDATION DRAIN SEWER CONNECTED	INDEPENDENT	WASTE WATER DRAIN C.I.	TILE
8'							

CLEAR WATER DRAIN C.I.	TILE	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILLO	ABANDONED WELL	SINK HOLE
			60'						

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

6. Well is intended to supply water for: Home

7. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10	Surface	44	6	44	100

10. FORMATIONS

Kind	From (ft.)	To (ft.)
Clay	Surface	8
Clay & stone	8	30
sandstone	30	55
limestone	55	100

8. CASING, LINER, CURBING, AND SCREEN

Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6	new black steel plain end 19.18	Surface	44

9. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
Clay	Surface	8
Cement	8	44

Well construction completed on 7-24-1970

11. MISCELLANEOUS DATA

Yield test: 4 Hrs. at 10 GPM

Depth from surface to normal water level 40 ft.

Depth to water level when pumping 50 ft.

Well is terminated 15 inches above below final grade

Well disinfected upon completion Yes No

Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on: 7-27-1970

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Coplan Registered Well Driller COMPLETE MAIL ADDRESS R3 Box 84 Roscoe, Wis., 53805

Please do not write in space below

COLIFORM TEST RESULT <u>706</u>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
------------------------------------	---------------	---------------	-----------	---------