

Section =
unlocatable

NOTE:
White Copy - Division's Copy
Green Copy - Driller's Copy
Yellow Copy - Owner's Copy

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Eastman

2. LOCATION ¼ Section NW Section 11 Township 8N Range 6W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE Michael Steiner
(Steiner)

OR - Grid or Street No. Street Name ADDRESS R7D Eastman 54626
NW Sec 14 ?? or SW Sec 11

AND - If available subdivision name, lot & block No. POST OFFICE Princeton, Wis. 53827

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 15'

Sanitary Bldg. Drain		Sanitary Bldg. Sewer		Floor Drain Connected To:		Storm Bldg. Drain		Storm Bldg. Sewer	
C.I.	Other	C.I.	Other	C.I. Sewer	Other Sewer	C.I.	Other	C.I.	Other

Street Sewer: San. Storm Other Sewers: C.I. Other Foundation Drain Connected to: Sewage Sump: C.I. Other Clearwater Sump: Clearwater Dr. Sewage Sump: Clearwater Sump

Septic Tank: 70' Holding Tank: Sewage Absorption Unit: 100'
Seepage Pit Seepage Bed Seepage Trench

Privy: Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumphouse Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Storage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Country home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>73</u>	<u>6</u>	<u>73</u>	<u>95</u>

9. FORMATIONS

Kind	From (ft.)	To (ft.)
<u>Clay & stone</u>	<u>Surface</u>	<u>55</u>
<u>limestone</u>	<u>55</u>	<u>95</u>

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel P.E. 18.97 A-53</u>	<u>Surface</u>	<u>73</u>
	<u>Valley Steel</u>		
	<u>Pitless adapter</u>		

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with Air Water

Rotary-air w/drilling mud Rotary-hammer & air

Rotary-w/drilling mud Reverse Rotary

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>8</u>
<u>Cement</u>	<u>8</u>	<u>73</u>

Well construction completed on 5-9-1980

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 5 GPM Well is terminated 10 inches above final grade below

Depth from surface to normal water level 60 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 68 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 5-13-1980

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Copron Registered Well Driller Complete Mail Address Boscobel, Wis. R2 Box 4 53805