

1. COUNTY Crawford CHECK (✓) ONE:  Town  Village  City Name Scott

2. LOCATION 1/4 Section NE Section 29 Township 9N Range 3W 3. NAME  OWNER  AGENT AT TIME OF DRILLING CHECK (✓) ONE  
OR - Grid or Street No. Street Name ADDRESS Jerry Seeley  
RFD.

AND - If available subdivision name, lot & block No. POST OFFICE Boscobel, Wis., 53805

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 15' Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to: Sewer Sewage Sump Clearwater Dr. Sewage Sump Clearwater Sump Sewage Sump C.I. Other Clearwater Sump Septic Tank Holding Tank Sewage Absorption Unit Seepage Pit Seepage Bed Seepage Trench 75'

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumphouse Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Country home 9. FORMATIONS

6. DRILLHOLE						9. FORMATIONS			
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
<u>10</u>	<u>0</u>	<u>40</u>	<u>6</u>	<u>40</u>	<u>80</u>	<u>Clay &amp; Stone</u>	<u>Surface</u>	<u>0</u>	<u>25</u>
						<u>hard shalestone</u>	<u>25</u>	<u>80</u>	

7. CASING, LINER, CURBING AND SCREEN Material, Weight, Specification & Method of Assembly

Dia. (in.)	From (ft.)	To (ft.)
<u>6</u>	<u>Surface</u>	<u>40</u>
<u>new black steel P.E. 18.97 A-53</u>		
<u>Kent steel</u>		
<u>Pitless adapter</u>		

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>8</u>
<u>Cement</u>	<u>8</u>	<u>40</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool  Rotary-hammer w/drilling mud & air  Jetting with  Air  Water

Rotary-air w/drilling mud  Rotary-hammer & air

Rotary-w/drilling mud  Reverse Rotary

Well construction completed on 11-22- 1979

11. MISCELLANEOUS DATA

Yield Test: 2 Hrs. at 5 GPM Well is terminated 12 inches  above  below final grade

Depth from surface to normal water level 30 Ft. Well disinfected upon completion  Yes  No

Depth of water level when pumping 42 Ft. Stabilized  Yes  No Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on 11-26- 1979

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Lopian Registered Well Driller Complete Mail Address Boscobel, Wis.  
R2 Box 4 53805