

AUG 5 1983

1. COUNTY Crawford CHECK (✓) ONE:  Town  Village  City Name Eastman

2. LOCATION NW of NW  Section 8 Township 8N Range 6W 3. NAME  OWNER  AGENT AT TIME OF DRILLING CHECK (✓) ONE  
OR - Grid or Street No. Street or Road Name ADDRESS Rt 1  
AND - If available subdivision name, lot & block No. POST OFFICE Eastman WI ZIP CODE 54626

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 15' Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to: Sewer Sewage Sump Clearwater Dr. Sewage Sump Clearwater Sump Sewage Absorption Unit: Seepage Pit Seepage Bed Seepage Trench 105' Manure Hopper or Retention or Pnuematic Tank

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit Earthen Manure Basin

Temporary Manure Stack or Platform Watertight Liquid Manure Tank or Basin Manure Pressure Pipe Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Manure Storage Basin Concrete Floor Only Concrete Floor and Partial Concrete Walls Other (Describe)

5. Well is intended to supply water for: home

6. DRILLHOLE

| Kind    | From (ft.) | To (ft.) | Kind | From (ft.) | To (ft.) |
|---------|------------|----------|------|------------|----------|
| 10      | 0          | 55       | 6    | 55         | 80       |
| Surface |            |          |      |            |          |

9. FORMATIONS

| Kind      | From (ft.) | To (ft.) |
|-----------|------------|----------|
| Clay      | 0          | 16       |
| sand rock | 16         | 80       |

7. CASING, LINER, CURBING AND SCREEN

| Dia. (in.) | Material, Weight, Specification | Mfg. & Method of Assembly | From (ft.) | To (ft.) |
|------------|---------------------------------|---------------------------|------------|----------|
| 6          | new black steel                 | PE 18.97                  | 0          | 55       |
|            | A-120                           | 1200 psi                  |            |          |
|            | A-53                            | Steel                     |            |          |
|            | Valley                          | Steel                     |            |          |
|            | Pitless                         | adapter                   |            |          |

10. TYPE OF DRILLING MACHINE USED

Cable Tool  Rotary-hammer w/drilling mud & air  Jetting with

Rotary-air w/drifting mud  Rotary-hammer & air  Air

Rotary-w/drilling mud  Reverse Rotary  Water

8. GROUT OR OTHER SEALING MATERIAL

| Kind   | From (ft.) | To (ft.) |
|--------|------------|----------|
| clay   | 0          | 8        |
| Cement | 8          | 55       |

Well construction completed on 7-7 1983

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 7 GPM Well is terminated 12 inches  above final grade  below

Depth from surface to normal water level 40 Ft. Well disinfected upon completion  Yes  No

Depth of water level when pumping 42 Ft. Stabilized  Yes  No Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on 7-12 1983

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Donald G. Kroschbaum Registered Well Driller Business Name and Complete Mailing Address Rt 4 Box 75  
Dons Well Drilling Escabel WI 53825