

WELL CONSTRUCTOR'S REPORT  
FORM 3300-15

SEP 29 1975

STATE OF WISCONSIN  
DEPARTMENT OF NATURAL RESOURCES  
Box 450  
Madison, Wisconsin 53701

AUG 27 1975

NOTE  
WHITE COPY - DIVISION'S COPY  
GREEN COPY - DRILLER'S COPY  
YELLOW COPY - OWNER'S COPY

1. COUNTY <i>Crawford</i>		CHECK ONE <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City			NAME <i>Scott</i>	
2. LOCATION - 1/4 Section <i>NE</i>		Section <i>32</i>	Township <i>9N</i>	Range <i>3W</i>	3. OWNER AT TIME OF DRILLING <i>Gary Kovars</i>	
OR - Grid or street no.		Street name			ADDRESS <i>R2</i>	
AND - If available subdivision name, lot & block no.				POST OFFICE <i>Boscobel, Wis., 53805</i>		
4. Distance in feet from well to nearest: (Record answer in appropriate block)		BUILDING <i>25'</i>	SANITARY SEWER C. I. <i>40'</i>	FLOOR DRAIN C. I. <input type="checkbox"/> TILE <input type="checkbox"/>	FOUNDATION DRAIN SEWER CONNECTED <input type="checkbox"/> INDEPENDENT <input type="checkbox"/>	WASTE WATER DRAIN C. I. <input type="checkbox"/> TILE <input type="checkbox"/>
CLEAR WATER DRAIN C. I. <input type="checkbox"/> TILE <input type="checkbox"/>	SEPTIC TANK <i>55'</i>	PRIVY	SEEPAGE PIT	ABSORPTION FIELD <i>60'</i>	BARN	SILLO
ABANDONED WELL						
SINK HOLE						

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: *Trailer home*

6. DRILLHOLE						9. FORMATIONS			
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
<i>10</i>	<i>Surface</i>	<i>40</i>	<i>6</i>	<i>40</i>	<i>60</i>	<i>Clay</i>	<i>Surface</i>	<i>25</i>	
						<i>limestone</i>	<i>25</i>	<i>60</i>	
7. CASING, LINER, CURBING, AND SCREEN									
Dia. (in.)	Kind and Weight		From (ft.)	To (ft.)					
<i>6</i>	<i>new black steel plain end 18.97</i>		<i>Surface</i>	<i>40</i>					

8. GROUT OR OTHER SEALING MATERIAL			10. TYPE OF DRILLING MACHINE USED		
Kind	From (ft.)	To (ft.)	<input type="checkbox"/> Cable Tool	<input type="checkbox"/> Direct Rotary	<input type="checkbox"/> Reverse Rotary
<i>puddled Clay</i>	<i>Surface</i>	<i>25</i>	<input type="checkbox"/> Rotary - air w/drilling mud	<input checked="" type="checkbox"/> Rotary - hammer with drilling mud & air	<input type="checkbox"/> Jetting with <input type="checkbox"/> Air <input type="checkbox"/> Water
<i>Cement</i>	<i>25</i>	<i>40</i>	Well construction completed on <i>8-7-</i> 19 <i>75</i>		

11. MISCELLANEOUS DATA			Well is terminated <i>10</i> inches <input checked="" type="checkbox"/> above <input type="checkbox"/> below final grade		
Yield test:	<i>2</i> Hrs. at	<i>5</i> GPM	Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Depth from surface to normal water level	<i>15</i>	ft.	Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Depth to water level when pumping	<i>25</i>	ft.			

Water sample sent to *Madison* laboratory on: *8-19-* 19 *75*

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE <i>Kenneth Coplan</i>	Registered Well Driller	COMPLETE MAIL ADDRESS <i>R3 Box 84 Boscobel, Wis., 53805</i>
------------------------------------	-------------------------	---

COLIFORM TEST RESULT <i>724</i>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
------------------------------------	---------------	---------------	-----------	---------