

WELL CONSTRUCTOR'S REPORT  
FORM 3300-15

STATE OF WISCONSIN  
DEPARTMENT OF NATURAL RESOURCES  
Box 450  
Madison, Wisconsin 53701

NOTE  
WHITE COPY - DIVISION'S COPY  
GREEN COPY - DRILLER'S COPY  
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE  Town  Village  City NAME Scott

2. LOCATION - 1/4 Section NE Section 32 Township 9N Range 3W 3. OWNER AT TIME OF DRILLING Charles Otto

OR - Grid or street no. Street name ADDRESS R7D

AND - If available subdivision name, lot & block no. POST OFFICE Boscobel, Wis., 53805

4. Distance in feet from well to nearest: (Record answer in appropriate block)

BUILDING	SANITARY	SEWER	FLOOR DRAIN	FOUNDATION DRAIN	WASTE WATER DRAIN
C. I.	C. I.	TILE	C. I.	SEWER CONNECTED	INDEPENDENT
<u>15'</u>	<u>20'</u>				

CLEAR WATER DRAIN	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO	ABANDONED WELL	SINK HOLE
C. I.	TILE							
	<u>65'</u>			<u>80'</u>				

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Country home

6. DRILLHOLE						9. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>280</u>	<u>6</u>	<u>280</u>	<u>380</u>	<u>Clay</u>	<u>Surface</u>	<u>15</u>
						<u>limestone</u>	<u>15</u>	<u>205</u>
						<u>Clay</u>	<u>205</u>	<u>220</u>
						<u>soft sandstone</u>	<u>220</u>	<u>260</u>
						<u>hard shalestone</u>	<u>260</u>	<u>380</u>

7. CASING, LINER, CURBING, AND SCREEN

Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel plain end 19.18</u>	<u>Surface</u>	<u>280</u>

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>15</u>
<u>Cement</u>	<u>15</u>	<u>280</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool  Direct Rotary  Reverse Rotary  
 Rotary - air w/drilling mud  Rotary - hammer with drilling mud & air  Jetting with  Air  Water

Well construction completed on 6-19-1972

11. MISCELLANEOUS DATA

Yield test: 3 Hrs. at 12 GPM

Well is terminated 10 inches  above  below final grade

Depth from surface to normal water level 300 ft. Well disinfected upon completion  Yes  No

Depth to water level when pumping 315 ft. Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on: 7-5-1972

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumphrooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Coplan Registered Well Driller COMPLETE MAIL ADDRESS Boscobel, Wis., 53805  
R3 Box 84

Please do not write in space below

COLIFORM TEST RESULT <u>725</u>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
------------------------------------	---------------	---------------	-----------	---------

REV. 3-71