

NOTE:

White Copy - Division's Copy
Green Copy - Driller's Copy
Yellow Copy - Owner's Copy

AUG 27 1979

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Haney

2. LOCATION NE Section 4 Township 9N Range 4W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE
ADDRESS Robert Zeman
RFD
POST OFFICE Gays Mills, Wis., 54631

4. Distance in feet from well to nearest: (Record answer in appropriate block) 10'

Sanitary Bldg. Drain		Sanitary Bldg. Sewer		Floor Drain Connected To:		Storm Bldg. Drain		Storm Bldg. Sewer	
C.I.	Other	C.I.	Other	C.I. Sewer	Other Sewer	C.I.	Other	C.I.	Other

Street Sewer		Other Sewers		Foundation Drain Connected to:		Sewage Sump		Clearwater Sump		Septic Tank		Holding Tank		Sewage Absorption Unit	
San.	Storm	C.I.	Other	Sewer	Clearwater Dr.	Sewage Sump	Clearwater Sump	C.I.	Other					Seepage Pit	<u>85'</u>
														Seepage Bed	
														Seepage Trench	

Privy	Pet Waste Pit	Pit: Nonconforming Existing		Subsurface Pumproom		Barn Gutter	Animal Barn Pen	Animal Yard	Silo With Pit	Glass Lined Storage Facility	Silo w/o Pit	Earthen Silage Storage Trench Or Pit	
		Well		Nonconforming Existing									
		Pump											
		Tank											

Temporary Manure Stack	Watertight Liquid Manure Tank	Solid Manure Storage Structure	Subsurface Gasoline or Oil Tank	Waste Pond or Land Disposal Unit (Specify Type)	Other (Give Description)

5. Well is intended to supply water for: Country home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>88</u>	<u>6</u>	<u>88</u>	<u>180</u>

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel P.E. 18.97 A-53</u>	<u>Surface</u>	<u>88</u>
	<u>Kent Steel</u>		
	<u>Pitless adapter</u>		

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>7</u>
<u>Cement</u>	<u>7</u>	<u>88</u>

9. FORMATIONS

Kind	From (ft.)	To (ft.)
<u>Clay & stone</u>	<u>Surface</u>	<u>15</u>
<u>soft shale stone</u>	<u>15</u>	<u>70</u>
<u>hard shale stone</u>	<u>70</u>	<u>155</u>
<u>sandstone</u>	<u>155</u>	<u>180</u>

10. TYPE OF DRILLING MACHINE USED

<input type="checkbox"/> Cable Tool	<input type="checkbox"/> Rotary-hammer w/drilling mud & air	<input type="checkbox"/> Jetting with
<input type="checkbox"/> Rotary-air w/drilling mud	<input checked="" type="checkbox"/> Rotary-hammer & air	<input type="checkbox"/> Air
<input type="checkbox"/> Rotary-w/drilling mud	<input type="checkbox"/> Reverse Rotary	<input type="checkbox"/> Water

11. MISCELLANEOUS DATA

Yield Test: 2 Hrs. at 5 GPM

Well is terminated 8 inches above final grade below

Depth from surface to normal water level 110 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 115 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 8-20-1979

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Copian Registered Well Driller Complete Mail Address Boscobel, Wis. R2 Box 4 53805

738