

1. COUNTY Crawford		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City		Name Haney	
2. LOCATION 1/4 Section SW Section 11 Township 9N Range 4W		3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE Elling Jones		ADDRESS R2	
OR - Grid or Street No. Street Name		POST OFFICE Sage Mills, Wis. 54631		AND - If available subdivision name, lot & block No.	
4. Distance in feet from well to nearest: (Record answer in appropriate block)		Building 15'		Sanitary Bldg. Drain C.I. Other	
		Sanitary Bldg. Sewer C.I. Other		Floor Drain Connected To: C.I. Sewer Other Sewer	
		Storm Bldg. Drain C.I. Other		Storm Bldg. Sewer C.I. Other	
Street Sewer		Other Sewers		Foundation Drain Connected to:	
San. Storm		C.I. Other		Sewage Sump C.I. Other	
		Clearwater Dr.		Clearwater Sump	
		Sewage Sump		Clearwater Sump	
Privy		Pet Waste Pit		Holding Tank	
Pit: Nonconforming Existing		Well		Septic Tank	
Well		Pump		Sewage Absorption Unit 7.5'	
Tank		Subsurface Pumproom		Seepage Pit	
		Nonconforming Existing		Seepage Bed	
		Barn Gutter		Seepage Trench	
		Animal Barn Pen		Glass Lined Storage Facility	
		Animal Yard		Silo w/o Pit	
		Silo With Pit		Earthen Silage Storage Trench Or Pit	
Temporary Manure Stack		Watertight Liquid Manure Tank		Solid Manure Storage Structure	
		Subsurface Gasoline or Oil Tank		Waste Pond or Land Disposal Unit (Specify Type)	
				Other (Give Description)	
5. Well is intended to supply water for: Country home		9. FORMATIONS			
6. DRILLHOLE		Kind		From (ft.)	To (ft.)
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10	Surface	63	6	63	80
7. CASING, LINER, CURBING AND SCREEN		Material, Weight, Specification & Method of Assembly		From (ft.)	To (ft.)
Dia. (in.)					
6	new black steel P.E. 18.97		Surface	0	63
	A-53				
	Valley Steel				
	Pitless adaptor				
8. GROUT OR OTHER SEALING MATERIAL		Kind		From (ft.)	To (ft.)
		Clay		Surface	7
		Cement		7	63
11. MISCELLANEOUS DATA		Yield Test: 4 Hrs. at 5 GPM		Well construction completed on March 8 19 78	
Depth from surface to normal water level 50 Ft.		Well is terminated 12 inches <input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below		Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Depth of water level when pumping 56 Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		Water sample sent to Madison laboratory on 3-21- 19 78	
Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.					
Signature Kenneth Coplan Registered Well Driller			Complete Mail Address R3 Box 84 Boscobel, Wis. 53805		