

WELL CONSTRUCTOR'S REPORT  
FORM 3300-15

AUG 27 1975

SEP 29 1975

STATE OF WISCONSIN  
DEPARTMENT OF NATURAL RESOURCES  
Box 450  
Madison, Wisconsin 53701

NOTE

WHITE COPY - DIVISION'S COPY  
GREEN COPY - DRILLER'S COPY  
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE  Town  Village  City Naney NAME

2. LOCATION - 1/4 Section NW Section 12 Township 9N Range 4W 3. OWNER AT TIME OF DRILLING Mrs. Wm. Ziemer

OR - Grid or street no. Street name ADDRESS R7D2

AND - If available subdivision name, lot & block no. POST OFFICE Gays Mills, Wis. 54631

4. Distance in feet from well to nearest: (Record answer in appropriate block)

BUILDING	SANITARY SEWER	FLOOR DRAIN	FOUNDATION DRAIN	WASTE WATER DRAIN
<u>15'</u>	C.I. <u>55'</u>	C.I. <u></u>	SEWER CONNECTED <u></u> INDEPENDENT <u></u>	C.I. <u></u> TILE <u>55'</u>

CLEAR WATER DRAIN	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILLO	ABANDONED WELL	SINK HOLE
C.I. <u></u> TILE <u></u>	<u>60'</u>	<u></u>	<u></u>	<u>75'</u>	<u>200'</u>	<u></u>	<u></u>	<u></u>

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Country home

6. DRILLHOLE						9. FORMATIONS			
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
<u>10</u>	<u>Surface</u>	<u>54</u>	<u>6</u>	<u>54</u>	<u>100</u>	<u>Clay</u>	<u>Surface</u>	<u>25</u>	
						<u>hard shale stone</u>	<u>25</u>	<u>80</u>	
						<u>sandstone</u>	<u>80</u>	<u>100</u>	

7. CASING, LINER, CURBING, AND SCREEN

Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel plain end 18.97</u>	<u>Surface</u>	<u>54</u>

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>puddled Clay</u>	<u>Surface</u>	<u>25</u>
<u>Cement</u>	<u>25</u>	<u>54</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool  Direct Rotary  Reverse Rotary

Rotary - air w/drilling mud  Rotary - hammer with drilling mud & air  Jetting with  Air  Water

Well construction completed on 8-13- 19 75

11. MISCELLANEOUS DATA

Yield test: 3 Hrs. at 8 GPM

Depth from surface to normal water level 30 ft.

Depth to water level when pumping 42 ft.

Well is terminated 10 inches  above  below final grade

Well disinfected upon completion  Yes  No

Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on: 8-19- 19 75

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumphrooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Coplan Registered Well Driller COMPLETE MAIL ADDRESS Boscobel, Wis. 53805

Please do not write in space below

COLIFORM TEST RESULT <u>741</u> REV. 3-71	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
---	---------------	---------------	-----------	---------