

WELL CONSTRUCTOR'S REPORT
FORM 3300-15

SEP 14 1974

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

NOTE

WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE Town Village City NAME Nancy

2. LOCATION - 1/4 Section NE Section 12 Township 9N Range 4W 3. OWNER AT TIME OF DRILLING Herbert Berkum

OR - Grid or street no. Street name ADDRESS R7D

AND - If available subdivision name, lot & block no. POST OFFICE Sage Mills, Wis., 54631

4. Distance in feet from well to nearest:

BUILDING	SANITARY SEWER	FLOOR DRAIN	FOUNDATION DRAIN	WASTE WATER DRAIN
C. I.	C. I.	C. I.	SEWER CONNECTED	INDEPENDENT
TILE	TILE	TILE		
<u>8'</u>	<u>24'</u>	<u>24'</u>		

CLEAR WATER DRAIN	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO	ABANDONED WELL	SINK HOLE
C. I.	TILE							
	<u>48'</u>			<u>125'</u>				

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Country home

6. DRILLHOLE						9. FORMATIONS			
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
<u>10</u>	<u>Surface</u>	<u>41</u>	<u>6</u>	<u>41</u>	<u>100</u>	<u>Clay</u>	<u>Surface</u>	<u>10</u>	
						<u>Clay, sand & gravel</u>	<u>10</u>	<u>30</u>	
						<u>shalestone</u>	<u>30</u>	<u>80</u>	
						<u>sandstone</u>	<u>80</u>	<u>100</u>	

7. CASING, LINER, CURBING, AND SCREEN

Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel plain end 18.97</u>	<u>Surface</u>	<u>41</u>

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>10</u>
<u>Cement</u>	<u>10</u>	<u>41</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool Direct Rotary Reverse Rotary

Rotary - air w/drilling mud Rotary - hammer with drilling mud & air Jetting with Air Water

Well construction completed on 8-30-1974

11. MISCELLANEOUS DATA

Yield test: 3 Hrs. at 5 GPM

Depth from surface to normal water level 43 ft.

Depth to water level when pumping 48 ft.

Well is terminated 15 inches above below final grade

Well disinfected upon completion Yes No

Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on: 9-9-1974

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumphrooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Copjian Registered Well Driller COMPLETE MAIL ADDRESS R3 Box 84 Boocohol, Wis., 53805

Please do not write in space below

COLIFORM TEST RESULT <u>743</u>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
------------------------------------	---------------	---------------	-----------	---------