

NOTE:

White Copy - Division's Copy
Green Copy - Driller's Copy
Yellow Copy - Owner's Copy

1. COUNTY <u>Crawford</u>		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City		Name <u>Haney</u>	
2. LOCATION ¼ Section <u>SE</u> Section <u>13</u> Township <u>9N</u> Range <u>4W</u>		3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE <u>Michael Wright</u>		ADDRESS <u>R2</u>	
OR - Grid or Street No. Street Name		POST OFFICE <u>Gay Mills, Wis. 54631</u>		AND - If available subdivision name, lot & block No.	
4. Distance in feet from well to nearest: (Record answer in appropriate block) <u>25'</u>		Building Sanitary Bldg. Drain Sanitary Bldg. Sewer Floor Drain Connected To: Storm Bldg. Drain Storm Bldg. Sewer		C.I. Other C.I. Other C.I. Sewer Other Sewer C.I. Other C.I. Other	
Street Sewer Other Sewers Foundation Drain Connected to: Sewage Sump Clearwater Sump Septic Holding Sewage Absorption Unit		San. Storm C.I. Other Sewer Sewage Sump Clearwater Dr. C.I. Other C.I. Other Tank Tank Seepage Pit Seepage Bed Seepage Trench			
Privy <u>75'</u> Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank		Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit			
Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)					
5. Well is intended to supply water for: <u>Country home</u>			9. FORMATIONS		
6. DRILLHOLE			Kind From (ft.) To (ft.)		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>40</u>	<u>6</u>	<u>40</u>	<u>80</u>
					<u>loose stone & Clay</u> <u>Surface</u> <u>0</u> <u>25</u>
					<u>hard shale stone</u> <u>25</u> <u>60</u>
					<u>sandstone</u> <u>60</u> <u>80</u>
7. CASING, LINER, CURBING AND SCREEN					
Material, Weight, Specification & Method of Assembly			From (ft.) To (ft.)		
Dia. (in.)			From (ft.)	To (ft.)	
<u>6</u>	<u>new black steel P.E. 18.97 A-53</u>		<u>Surface</u>	<u>0</u> <u>40</u>	
	<u>Kent steel</u>				
	<u>Hand pump</u>				
8. GROUT OR OTHER SEALING MATERIAL			10. TYPE OF DRILLING MACHINE USED		
Kind From (ft.) To (ft.)			<input type="checkbox"/> Cable Tool <input type="checkbox"/> Rotary-hammer w/drilling mud & air <input type="checkbox"/> Jetting with		
<u>Clay</u> <u>Surface</u> <u>0</u> <u>2</u>			<input type="checkbox"/> Rotary-air w/drilling mud <input checked="" type="checkbox"/> Rotary-hammer & air <input type="checkbox"/> Air		
<u>Cement</u> <u>2</u> <u>40</u>			<input type="checkbox"/> Rotary-w/drilling mud <input type="checkbox"/> Reverse Rotary <input type="checkbox"/> Water		
11. MISCELLANEOUS DATA			Well construction completed on <u>6-28-</u> <u>1979</u>		
Yield Test: <u>2</u> Hrs. at <u>5</u> GPM			Well is terminated <u>12</u> inches <input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below		
Depth from surface to normal water level <u>60</u> Ft.			Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Depth of water level when pumping <u>60</u> Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Water sample sent to <u>Madison</u> laboratory on <u>7-10-</u> <u>1979</u>					

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature <u>Kenneth Eopian</u> Registered Well Driller	Complete Mail Address <u>R2 Box 4</u> <u>Boscobel, Wis.</u> <u>53805</u>
---	---