

1. COUNTY <u>Crawford</u>		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City		Name <u>Haney</u>	
2. LOCATION ¼ Section <u>NE</u> Section <u>13</u> Township <u>9N</u> Range <u>4W</u>		3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE <u>Ron Lays</u>			
OR - Grid or Street No. Street Name		ADDRESS <u>R 7 D</u>			
AND - If available subdivision name, lot & block No.		POST OFFICE <u>Says Mills, Wis., 54631</u>			
4. Distance in feet from well to nearest: (Record answer in appropriate block) <u>300'</u>		Building		Sanitary Bldg. Drain	
		Sanitary Bldg. Sewer		Floor Drain Connected To:	
		Storm Bldg. Drain		Storm Bldg. Sewer	
		C.I.		C.I.	
		Other		Other	
		C.I. Sewer		Other Sewer	
		C.I.		Other	
		C.I.		Other	
Street Sewer		Other Sewers		Foundation Drain Connected to:	
San. Storm		C.I. Other		Sewage Sump	
				Clearwater Sump	
				Septic Tank	
				Holding Tank	
				Sewage Absorption Unit	
				Seepage Pit	
				Seepage Bed	
				Seepage Trench	
Privy		Pet Waste Pit		Pit: Nonconforming Existing	
				Subsurface Pumproom	
				Barn Gutter	
				Animal Barn Pen	
				Animal Yard	
				Silo With Pit	
				Glass Lined Storage Facility	
				Silo w/o Pit	
				Earthen Silage Storage Trench Or Pit	
Temporary Manure Stack		Watertight Liquid Manure Tank		Solid Manure Storage Structure	
				Subsurface Gasoline or Oil Tank	
				Waste Pond or Land Disposal Unit (Specify Type)	
				Other (Give Description)	
5. Well is intended to supply water for: <u>Country home</u>				9. FORMATIONS	
6. DRILLHOLE				Kind	
				From (ft.)	
				To (ft.)	
Dia. (in.)		From (ft.)		To (ft.)	
10		Surface		178	
6		178		260	
				Clay & stone	
				Surface 0	
				10	
				123	
				160	
				250	
				260	
7. CASING, LINER, CURBING AND SCREEN					
Material, Weight, Specification & Method of Assembly				From (ft.)	
				To (ft.)	
Dia. (in.)		From (ft.)		To (ft.)	
6		Surface		178	
<u>new black steel P.E. 18.97 A-53</u>					
<u>Valley Steel</u>					
<u>Hand pump</u>					
8. GROUT OR OTHER SEALING MATERIAL				10. TYPE OF DRILLING MACHINE USED	
Kind				From (ft.)	
				To (ft.)	
Clay		Surface		0	
Cement		7		178	
				<input type="checkbox"/> Cable Tool	
				<input type="checkbox"/> Rotary-air w/drilling mud	
				<input type="checkbox"/> Rotary-w/drilling mud	
				<input type="checkbox"/> Rotary-hammer w/drilling mud & air	
				<input checked="" type="checkbox"/> Rotary-hammer & air	
				<input type="checkbox"/> Reverse Rotary	
				<input type="checkbox"/> Jetting with	
				<input type="checkbox"/> Air	
				<input type="checkbox"/> Water	
11. MISCELLANEOUS DATA				Well construction completed on <u>9-7-1979</u>	
Yield Test: <u>2</u> Hrs. at <u>15</u> GPM				Well is terminated <u>8</u> inches <input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below	
Depth from surface to normal water level <u>190</u> Ft.				Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Depth of water level when pumping <u>205</u> Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No				Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Water sample sent to <u>Madison</u> laboratory on <u>9-24-1979</u>					
Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.					
Signature <u>Kenneth Lopian</u> Registered Well Driller				Complete Mail Address <u>Boocobel, Wis., R 2 Box 4 53805</u>	

745