

WELL CONSTRUCTOR'S REPORT  
FORM 3300-15

NOTE MAR 22 1973

STATE OF WISCONSIN  
DEPARTMENT OF NATURAL RESOURCES  
Box 450  
Madison, Wisconsin 53701

WHITE COPY - DIVISION'S COPY  
GREEN COPY - DRILLER'S COPY  
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE  Town  Village  City NAME Naney

2. LOCATION - 1/4 Section SW Section 20 Township 9N Range 4 W

3. OWNER AT TIME OF DRILLING Karl Childs

OR - Grid or street no. Street name ADDRESS R2

AND - If available subdivision name, lot & block no. POST OFFICE Sage Mills, Wis. 54631

4. Distance in feet from well to nearest:

BUILDING C. I.	SANITARY SEWER TILE	FLOOR DRAIN C. I.	TILE	FOUNDATION DRAIN SEWER CONNECTED	INDEPENDENT	WASTE WATER DRAIN C. I.	TILE
<u>75'</u>	<u>80'</u>	<u>80'</u>					

(Record answer in appropriate block)

CLEAR WATER DRAIN C. I.	SEPTIC TANK TILE	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO	ABANDONED WELL	SINK HOLE
	<u>95'</u>		<u>100'</u>		<u>200'</u>			

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Farm-home

6. DRILLHOLE						9. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>70</u>	<u>6</u>	<u>70</u>	<u>100</u>	<u>Clay</u>	<u>Surface</u>	<u>15</u>
						<u>limestone</u>	<u>15</u>	<u>50</u>
						<u>hard shalestone</u>	<u>50</u>	<u>80</u>
						<u>sandstone</u>	<u>80</u>	<u>100</u>

7. CASING, LINER, CURBING, AND SCREEN

Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel plain end 19.18</u>	<u>Surface</u>	<u>70</u>

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>15</u>
<u>Cement</u>	<u>15</u>	<u>70</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool  Direct Rotary  Reverse Rotary

Rotary - air w/drilling mud  Rotary - hammer with drilling mud & air  Jetting with  Air  Water

Well construction completed on 2-24-1973

11. MISCELLANEOUS DATA

Yield test: 2 Hrs. at 15 GPM

Depth from surface to normal water level 60 ft.

Depth to water level when pumping 68 ft.

Well is terminated 10 inches  above  below final grade

Well disinfected upon completion  Yes  No

Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on: 3-19-1973

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumphrooms, access pits, etc., should be given on reverse side.

SIGNATURE Benneth Popian Registered Well Driller COMPLETE MAIL ADDRESS Boscobel R3 Box 84 Wis., 53805

Please do not write in space below

COLIFORM TEST RESULT	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
<u>749</u>				