

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Eastman JUN 16 1983

2. LOCATION NW of SW Section 20 Township 8N Range 6W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE Tom Kazolka

OR - Grid or Street No. Street or Road Name ADDRESS Prairie Du Chen WI 53821

AND - If available subdivision name, lot & block No. POST OFFICE ZIP CODE

4. Distance in feet from well to nearest: (Record answer in appropriate block)

Building	Sanitary Bldg. Drain	Sanitary Bldg. Sewer	Floor Drain Connected To	Storm Bldg. Drain	Storm Bldg. Sewer
<u>15'</u>	C.I. Other	C.I. Other	C.I. Sewer Other Sewer	C.I. Other	C.I. Other

Street Sewer Other Sewers Foundation Drain Connected to Sewage Sump Clearwater Sump Septic/Holding Tank Sewage Absorption Unit Manure Hopper or Retention or Pnuematic Tank

San. Storm C.I. Other Sewer Sewage Sump C.I. Other Clearwater Sump Clearwater Sump Seepage Pit Seepage Bed 62' Seepage Trench

Privy Pet Waste Pit Pit: Nonconforming Existing Subsurface Pumproom Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit Earthen Manure Basin

Temporary Manure Stack or Platform Watertight Liquid Manure Tank or Basin Manure Pressure Pipe Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Manure Storage Basin Concrete Floor Only Concrete Floor and Partial Concrete Walls Other (Describe)

5. Well is intended to supply water for: Country home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>280</u>	<u>6</u>	<u>280</u>	<u>520</u>

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification Mfg. & Method of Assembly	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel PE 18.97 A120-1200psi Valley Steel Pitless adapter</u>	<u>Surface</u>	<u>280</u>

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>clay</u>	<u>Surface</u>	<u>8</u>
<u>Cement</u>	<u>8</u>	<u>280</u>

9. FORMATIONS

Kind	From (ft.)	To (ft.)
<u>clay</u>	<u>Surface</u>	<u>10</u>
<u>Lime Rock</u>	<u>10</u>	<u>90</u>
<u>Sand Rock</u>	<u>90</u>	<u>130</u>
<u>Lime Rock</u>	<u>130</u>	<u>440</u>
<u>Sand Rock</u>	<u>440</u>	<u>520</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with Air Water

Rotary-air w/drilling mud Rotary-hammer & air Reverse Rotary

Rotary-w/drilling mud

Well construction completed on 12-3-82

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 7 GPM Well is terminated 12 inches above final grade below

Depth from surface to normal water level 460 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 462 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 1983

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Donald C. Kerschbaum Registered Well Driller Business Name and Complete Mailing Address Box 75
Dons Well Drilling Boscobel WI 53805